



*Borehole Yield and Quality Testing at
Ackermans, Blackheath.*

REPORT:

GEOSS Report No: 2023/11-15

PREPARED FOR:

Johan Roos
KLS Consulting Engineers
Email: johan.roos@kls.co.za

PREPARED BY:

Reuben Lazarus
GEOSS South Africa (Pty) Ltd
Unit 12, Technostell Building,
9 Quantum Street,
Technopark
Stellenbosch 7600
Tel: (021) 880-1079
Email: info@geoss.co.za
(www.geoss.co.za)

20 November 2023



EXECUTIVE SUMMARY

GEOSS South Africa (Pty) Ltd was appointed by Johan Roos from KLS Consulting Engineers to conduct yield and groundwater quality testing of one borehole at Ackermans, Blackheath. The yield testing was undertaken by GEOSS SA from 6 to 9 November 2023. This included a Step Test, CDT and Recovery Test at the borehole and sampling of the groundwater for chemical analysis. It is recommended that groundwater abstraction occur within the below-mentioned parameters from the tested borehole. Aquifer over-abstraction is unlikely to occur if these rates are adhered to and if the borehole is managed through long-term monitoring data.

Borehole Details				
Borehole Name	Latitude (DD)	Longitude (DD)	Borehole Depth (m)	Inner Diameter (mm)
AB_BH1	-33.95713°	18.67164°	84	135
Abstraction Recommendations				
Borehole Name	Abstraction rate (L/s)	Abstraction Duration (hrs)	Recovery Duration (hrs)	Possible Volume Abstracted (L/d)
AB_BH1	2.9	24	0	250 560
Pump Installation Details				
Borehole Name	Pump Installation Depth (mbgl)	Critical Water Level (mbgl)	Dynamic Water Level (mbgl)*	Rest Water Level (mbgl)
AB_BH1	52	50	30	3.08

* Typical water level expected during long-term production

Through long term water level monitoring data, the abstraction volumes can be optimised by adjusting the abstraction rate if required. It is recommended that the borehole is equipped with a variable frequency drive. This enables adjustments to the flow rate to be made if required, as determined by the hydrogeological analysis of water level and flow rate monitoring data.

From the laboratory results, groundwater from AB_BH1 is of poor quality for potable supply. The primary cause of the poor groundwater quality is the elevated turbidity (22.5 NTU). According to the SANS 241-1:2015 standards the elevated turbidity will have aesthetic effects on the water such as poor colour. Similarly, the iron (1.935 mg/L), manganese (0.114 mg/L) and chloride (328.15 mg/L) will have aesthetic effects on the water such as poor taste and colour. Due to the elevated iron concentration, iron biofouling is likely to occur in the borehole if the borehole is not managed optimally. This will result in the clogging of the borehole as well as abstraction infrastructure. The groundwater from AB_BH1 is currently not suitable for human consumption without treatment. Should the water be used for irrigation, crop selection should take into account the elevated chloride concentration.

To address the potential for iron to clog the borehole and abstraction infrastructure, it is recommended to maintain a constant and continuous pumping schedule as much as possible. Thus, should a daily volume of less than 250 560 L/d be required, it is recommended to decrease the

pumping rate and not the pumping duration. By pumping continuously instead of on a stop-start schedule, iron oxidation in the borehole is minimized, decreasing the amount of iron precipitation inside the boreholes and pumps.

To facilitate monitoring and informed management of the borehole, it is recommended to equip borehole with the following monitoring infrastructure and equipment:

- Installation of a 32 mm (inner diameter, class 10) observation pipe from the pump depth to the surface, closed at the bottom and slotted for the bottom 5 – 10 m. This was done during the testing activities in November 2023.
- Installation of an electronic water level logger (for automated water level monitoring)
- Installation of a sampling tap (to monitor water quality)
- Installation of a flow volume meter (to monitor abstraction rates and volumes)

This report is an important document for obtaining the legal compliance with regard to the use of the groundwater with the Department of Water and Sanitation, but does not constitute a Geohydrological Assessment report in support of a WULA, which would need to incorporate information from this report.

TABLE OF CONTENTS

1. INTRODUCTION	1
2. YIELD TESTING.....	1
2.1 Methodology.....	1
2.2 Yield Testing at AB_BH1.....	5
3. WATER QUALITY ANALYSIS	8
4. RECOMMENDATIONS.....	12
5. REFERENCES	14
6. APPENDIX A: ESTIMATED BOREHOLE LOG.....	15
7. APPENDIX B: YIELD TEST DATA.....	17
8. APPENDIX C: WATER QUALITY	22
9. APPENDIX D: MONITORING INFRASTRUCTURE DIAGRAM	26
10. APPENDIX E: YIELD TEST DATA ANALYSIS	29

LIST OF FIGURES

Figure 1: AB_BH1 before (left) and after (right) testing.....	1
Figure 2: Borehole Locality Map	2
Figure 3: Geological Map with Property Boundary and Tested Borehole Position (1:250 000 Geological Map Series, 3222 Beaufort West)(CGS, 1979).....	3
Figure 4: Step Test drawdown data for AB_BH1.....	5
Figure 5: Semi-Log Plot of drawdown during the CDT of AB_BH1 (4.6 L/s).....	6
Figure 6: Time-series drawdown and recovery for AB_BH1 (4.6 L/s).....	6
Figure 7: Radius of influence for AB_BH1 at the recommended sustainable yield (2.5 L/s).....	7
Figure 8: Stiff diagram of the groundwater sample.....	11
Figure 9: SAR diagram of the groundwater sample.....	12

LIST OF TABLES

Table 1: Borehole Details	1
Table 2: Yield Determination - AB_BH1.....	7
Table 3: Classification table for specific limits.....	8
Table 4: Classification table for the groundwater results (DWAF, 1998)	8
Table 5: Production borehole results classified according to SANS241-1:2015	9
Table 6: Classified production borehole results according to DWAF 1998.	10
Table 7: Borehole Abstraction Recommendations	12

ABBREVIATIONS

AD	available drawdown
bh	borehole
CDT	constant discharge test
DWA	Department of Water Affairs (pre- 1994)
DWAF	Department of Water Affairs and Forestry (1994 – 2009)
DWS	Department of Water and Sanitation (2009 –)
ID	inner diameter
L/s	litres per second
L/d	litres per day
m ² /d	meters squared per day
m	metres
mbgl	metres below ground level
RWL	rest water level below ground level
T	Transmissivity

GLOSSARY OF TERMS

Aquifer: a geological formation, which has structures or textures that hold water or permit appreciable water movement through them [from National Water Act (Act No. 36 of 1998)].

Available drawdown: Available drawdown in a borehole is the difference between the rest water level or piezometric surface and the depth that the water level may drop to (typically major water bearing unit, boundary inflection or pump depth).

Dynamic water level: the stabilised water level in the borehole during production over long periods of time.

Groundwater: water found in the subsurface in the saturated zone below the water table or piezometric surface i.e., the water table marks the upper surface of groundwater systems.

Rest water level: The groundwater level in a borehole not influenced by abstraction or artificial recharge.

Sustainable yield: Sustainable yield is defined as the rate of withdrawal that can be sustained by an aquifer without causing an unacceptable decline in the hydraulic head or deterioration in water quality in the aquifer.

Transmissivity: The rate at which water is transmitted through a unit width of an aquifer under a unit hydraulic gradient.

Suggested citation for this report:

GEOSS (2023). Borehole Yield and Quality Testing at Ackermans, Blackheath. Report Number: 2023/11-15. GEOSS South Africa (Pty) Ltd. Stellenbosch, South Africa.

Cover photo:

AB_BH1 during testing.

GEOSS project number:

2023_10-5315_A

Reviewed by:

Ashleigh Lakshuman (20 November 2023) and Julian Conrad (20 November 2023).

1. INTRODUCTION

GEOSS South Africa (Pty) Ltd was appointed by Johan Roos from KLS Consulting Engineers to conduct yield and water quality testing of one borehole at Ackermans, Blackheath.

The borehole was tested by GEOSS SA from 6 to 9 November 2023, details of this are presented in this report. The borehole's details are presented in **Table 1** below and spatially in **Figure 2**. A borehole drill log is presented in **Appendix A**. The geological setting of the area indicates that the borehole is drilled through the sandy loam of the Springfontyn formation into the underlying greywacke and phyllites of the Tygerberg formation (**Figure 3**).

Table 1: Borehole Details

Borehole	Latitude (DD-WGS84)	Longitude (DD-WGS84)	Depth (m)
AB_BH1	-33.95713°	18.67164°	84



Figure 1: AB_BH1 before (left) and after (right) testing.

2. YIELD TESTING

2.1 Methodology

The yield testing was undertaken by GEOSS SA from 6 to 9 November 2023 and carried out according to the National Standard (SANS 10299-4:2003, Part 4 – Test pumping of water boreholes). This included a Step Test, Constant Discharge Test (CDT) and recovery monitoring of the borehole. For the Step Test, a borehole is pumped at a constant rate for one-hour intervals and the flow rates are incrementally increased for each step. This test is followed by a Constant Discharge Test where the borehole is pumped at a constant rate for an extended period of time, followed by recovery monitoring. The water level drawdown is monitored at pre-determined intervals during these tests (drawdown refers to the difference in water level from the rest water level (RWL) measured before commencement of the yield test). Raw data and measurements taken during the yield tests are presented in **Appendix B**.



Figure 2: Borehole Locality Map




Figure 3: Geological Map with Property Boundary and Tested Borehole Position (1:50 000 Geological Map Series, 3318 DC Bellville)(CGS, 1984).

The yield test data was analysed using the excel-based FC program, developed by the IGS (Institute for Groundwater Studies) in Bloemfontein. The sustainable yield of the borehole was calculated based upon long-term extrapolations of the CDT data according to (1) the Cooper-Jacob approximation of the Theis solution for confined aquifers, (2) the Barker Generalised Radial Flow Model (GRF) for hydraulic tests in fractured rock and (3) the Flow Characteristic (FC) method(s) using first and second derivative calculations. Boundary conditions are accounted for in multiplication factors to the rate of drawdown (derivatives), according to each of the above three methods. These three methods are briefly described below.

1. The Cooper-Jacob approximation of the Theis solution for confined aquifers was designed for porous media aquifers, where infinite acting radial flow (IARF) was observed during the pumping of a borehole. The application of this method to fractured aquifers was discussed by Meier et al (1998), concluding that T estimates using the Cooper-Jacob analysis gave an effective T for the fracture zone. The Cooper-Jacob analysis (and more accurately the Theis method) is therefore viable for analysing pumping test data for fractured aquifers where IARF is observed. The parameters are then used to predict theoretical long-term drawdowns.
2. The Barker GRF Model (Barker, 1988) uses fracture hydraulic conductivity, fracture storativity and flow domain to predict drawdown due to abstraction in a borehole in a fractured medium. By changing these values, a curve of drawdown predictions can be made to fit real-world data and therefore predict theoretical long-term drawdowns.
3. The FC methods are the Basic FC, the FC Inflection Point and the FC Non-Linear. The Basic FC and the FC Inflection Point methods make use of the derivatives of the drawdown data to predict theoretical long-term drawdowns and the scale-back factors are applied to selected available drawdowns. The FC Non-Linear method uses curve fitting of the Step Test data to predict theoretical long-term drawdowns. Due to the short nature of the Step Test, this method is usually not included if the other methods of analysis differ from it.

In all three methods, the available drawdown was carefully selected to ensure that the flow regime described by the analytical solution is not extrapolated beyond its applicable depth, which may easily result in an overuse of the resource. For AB_BH1 this was 50 m (54 mbgl), based on the first fracture intersected in the borehole. A two-year extrapolation time without recharge to the aquifer was selected as per the recommendations within the FC method program.

Water samples were collected at the end of the yield test and submitted for inorganic chemical analyses.

2.2 Yield Testing at AB_BH1

The yield testing was conducted between the 6th and the 9th of November 2023. The borehole was measured to a depth of 84 meters below ground level (mbgl). The test pump was installed at a depth of 78.12 mbgl, with the observation pipe ending at 75.32 mbgl. A 7.5 kw submersible pump was used to conduct the testing. The size of the pump was limited by the 135 mm steel casing installed in the borehole. The rest water level (RWL) at the start of the test was 3.08 mbgl.

During the step test, the water level was drawn down 17.08 meters below the rest water level (20.16 mbgl) during the 4th step at a rate of 4.8 L/s (17 280 L/hour, pump max). **Figure 4** shows the time-series drawdown for the Step Test.




Figure 4: Step Test drawdown data for AB_BH1.

The water level was left to recover overnight. Before starting the CDT, the water level recovered to 3.97 mbgl. Based on the results of the Step Test, the planned 24-hour CDT was conducted at a rate of 4.6 L/s (16 560 L/hour). At the end of the 24-hour period, the water level had drawn down 23.6 meters below the rest water level (27.57 mbgl).

The semi-log plot of the drawdown from the CDT is presented in **Figure 5**. The available drawdown (AD) is indicated with the horizontal red line at 50 m.



Figure 5: Semi-Log Plot of drawdown during the CDT of AB_BH1 (4.6 L/s).

The recovery of the water level was monitored after the CDT and is presented in **Figure 6**. The recovery was moderate, reaching 95.8% in 24 hours. Monitoring will be essential to determine the long term recovery of the borehole.




Figure 6: Time-series drawdown and recovery for AB_BH1 (4.6 L/s).

Several methods were used to assess the yield test data as presented in **Table 2**. It is recommended that the borehole can be abstracted from at a rate of up to 2.9 L/s (10 440 L/hour) for up to

24 hours per day. The assessments were based on an available drawdown (AD) of 50 meters below the RWL of the CDT which equates to 54 mbgl.

Table 2: Yield Determination - AB_BH1

AB_BH1			
Method	Sustainable Yield (L/s)	Late *T (m ² /d)	**AD used (m)
Basic FC	3.5	11.3	50.0
Cooper-Jacob	2.8	11.4	50.0
FC Non-Linear	2.4	19	50.0
Barker	2.9		50.0
Average Q_{sust} (L/s)	2.9		
Recommended Abstraction			
Abstraction Rate (L/s)	Abstraction Duration (hours)	Recovery Duration (hours)	
2.9	24	0	

**AD- Available Drawdown

* T – Transmissivity

No boreholes were monitored during the testing of AB_BH1. Transmissivity was calculated through the Theis method using the drawdown response in AB_BH1. The transmissivity of the system was calculated at 11.4 m²/d. A storativity value of 5x10⁻⁴ was used for the radius of influence calculation based on an average expected value of confined aquifers as report by (Todd, 1980). Based on the aquifer parameters the radius of influence was calculated for the recommended sustainable yield of the borehole. A drawdown of up to 6.3 meters can be expected 1 kilometre away from AB_BH1 at the recommended sustainable rate (2.9 L/s for 24 hours per day) after 2 years of abstraction without recharge (Figure 7). It must be noted that the Cooper-Jacob modelling of radius of influence is based on a homogenous, confined aquifer and therefore does not account for the heterogeneity associated with secondary aquifers (fractured rock). Thus, the radius of influence model will only provide an indication of how abstraction at AB_BH1 will impact the water level in the fracture network. This suggests that the cone of depression will not expand equivalently in all directions surrounding the borehole, but will rather propagate along the fracture network within the secondary aquifer.




Figure 7: Radius of influence for AB_BH1 at the recommended sustainable yield (2.9 L/s).

3. WATER QUALITY ANALYSIS

Groundwater samples were collected from the borehole at the end of the yield test and submitted for inorganic chemical analyses to a SANAS accredited laboratory (Vinlab) in the Western Cape. The certificate of analysis for the sample is presented in **Appendix C**. The chemistry results obtained for the borehole have been classified according to the SANS241-1: 2015 standards for domestic water (**Table 3**). **Table 5** presents the water chemistry analysis results, colour coded according to the SANS241-1: 2015 drinking water assessment standards.

Table 3: Classification table for specific limits

Acute Health	Chronic Health	Aesthetic	Operational	Acceptable
---------------------	-----------------------	------------------	--------------------	-------------------

The limits and associated risks for domestic water as determined by the South African National Standard (SANS) 241:2015 are as follows, where:

- Health risks: parameters falling outside these limits may cause acute or chronic health problems in individuals.
- Aesthetic risks: parameters falling outside these limits indicate that water is visually, aromatically or palatably unacceptable.
- Operational risks: parameters falling outside these limits may indicate that operational procedures to ensure water quality standards are met may have failed.

The chemistry results obtained have also been classified according to the DWAF (1998) standards for domestic water. **Table 4** enables an evaluation of the water quality with regards to the various parameters measured (DWAF, 1998). **Table 6** presents the water chemistry analysis results colour coded according to the DWAF drinking water assessment standards.

Table 4: Classification table for the groundwater results (DWAF, 1998)

Blue	(Class 0)	Ideal water quality - suitable for lifetime use.
Green	(Class I)	Good water quality - suitable for use, rare instances of negative effects.
Yellow	(Class II)	Marginal water quality - conditionally acceptable. Negative effects may occur.
Red	(Class III)	Poor water quality - unsuitable for use without treatment. Chronic effects may occur.
Purple	(Class IV)	Dangerous water quality - totally unsuitable for use. Acute effects may occur.

Table 5: Production borehole results classified according to SANS241-1:2015

Analyses	AB_BH1	SANS 241-1:2015
Date and Time Sampled	08/11/2023 06:30	
pH (at 25 °C)	7.1	5.0 ≤ Operational ≤ 9.7
Conductivity (mS/m) (at 25 °C)	136.1	Aesthetic ≤170
Total Dissolved Solids (mg/L)	922.76	Aesthetic ≤1200
Turbidity (NTU)	22.50	Operational ≤1 Aesthetic ≤5
Colour (mg/L as Pt)	<15	Aesthetic ≤15
Sodium (mg/L as Na)	177	Aesthetic ≤200
Potassium (mg/L as K)	3	N/A
Magnesium (mg/L as Mg)	29	N/A
Calcium (mg/L as Ca)	50	N/A
Chloride (mg/L as Cl)	328.15	Aesthetic ≤300
Sulphate (mg/L as SO ₄)	7.66	Aesthetic ≤250 Acute ≤500
Nitrate & Nitrite Nitrogen (mg/L as N)	0.068	≤1 Acute Health
Nitrate Nitrogen (mg/L as N)	<1.00	Acute Health ≤11
Nitrite Nitrogen (mg/L as N)	<0.05	Acute Health ≤0.9
Ammonia Nitrogen (mg/L as N)	0.19	Aesthetic ≤1.5
Total Alkalinity (mg/L as CaCO ₃)	173.2	N/A
Total Hardness (mg/L as CaCO ₃)	243.9	N/A
Fluoride (mg/L as F)	<0.15	Chronic Health ≤1.5
Aluminium (mg/L as Al)	<0.008	Operational ≤0.3
Total Chromium (mg/L as Cr)	<0.004	Chronic Health ≤0.05
Manganese (mg/L as Mn)	0.114	Aesthetic ≤0.1 Chronic ≤0.4
Iron (mg/L as Fe)	1.935	Aesthetic ≤0.3 Chronic ≤2
Nickel (mg/L as Ni)	<0.008	Chronic Health ≤0.07
Copper (mg/L as Cu)	0.010	Chronic Health ≤2
Zinc (mg/L as Zn)	<0.008	Aesthetic ≤5
Arsenic (mg/L as As)	<0.010	Chronic Health ≤0.01
Selenium (mg/L as Se)	<0.008	Chronic Health ≤0.04
Cadmium (mg/L as Cd)	0.001	Chronic Health ≤0.003
Antimony (mg/L as Sb)	<0.013	Chronic Health ≤0.02
Mercury (mg/L as Hg)	<0.001	Chronic Health ≤0.006
Lead (mg/L as Pb)	0.009	Chronic Health ≤0.01
Uranium (mg/L as U)	<0.028	Chronic Health ≤0.03
Cyanide (mg/L as CN ⁻)	<0.01	Acute Health ≤0.2
Total Organic Carbon (mg/L as C)	0.54	N/A
Charge Balance Error %	1.5	≥ -5 - ≤5 Acceptable

Table 6: Classified production borehole results according to DWAF 1998.

	AB_BH1	DWA (1998) Drinking Water Assessment Guide				
		Class 0	Class I	Class II	Class III	Class IV
		Ideal	Good	Marginal	Poor	Dangerous
Date and Time Sampled	08/11/2023 06:30					
pH	7.1	5-9.5	4.5-5 & 9.5-10	4-4.5 & 10-10.5	3-4 & 10.5-11	< 3 & >11
Conductivity (mS/m)	136.1	<70	70-150	150-370	370-520	>520
Turbidity (NTU)	22.50	<0.1	0.1-1	1.0-20	20-50	>50
		mg/L				
Total Dissolved Solids	922.76	<450	450-1000	1000-2400	2400-3400	>3400
Sodium (as Na)	177	<100	100-200	200-400	400-1000	>1000
Potassium (as K)	3	<25	25-50	50-100	100-500	>500
Magnesium (as Mg)	29	<70	70-100	100-200	200-400	>400
Calcium (as Ca)	50	<80	80-150	150-300	>300	
Chloride (as Cl)	328.15	<100	100-200	200-600	600-1200	>1200
Sulphate (as SO ₄)	7.66	<200	200-400	400-600	600-1000	>1000
Nitrate & Nitrite (as N)	0.068	<6	6.0-10	10.0-20	20-40	>40
Fluoride (as F)	<0.15	<0.7	0.7-1.0	1.0-1.5	1.5-3.5	>3.5
Manganese (as Mn)	0.114	<0.1	0.1-0.4	0.4-4	4.0-10.0	>10
Iron (as Fe)	1.935	<0.5	0.5-1.0	1.0-5.0	5.0-10.0	>10
Copper (as Cu)	0.010	<1	1-1.3	1.3-2	2.0-15	>15
Zinc (as Zn)	<0.008	<20	>20			
Arsenic (as As)	<0.010	<0.010	0.01-0.05	0.05-0.2	0.2-2.0	>2.0
Cadmium (as Cd)	0.001	<0.003	0.003-0.005	0.005-0.020	0.020-0.050	>0.050
Hardness (as CaCO ₃)	243.900	<200	200-300	300-600	>600	
Charge Balance Error %	1.5	≥ -5 - ≤ 5 Acceptable				

From the chemical results presented in **Table 5** and **Table 6**, groundwater from AB_BH1 is of poor quality for potable supply. The primary cause of the poor groundwater quality is the elevated turbidity (22.5 NTU). According to the SANS 241-1:2015 standards the elevated turbidity will have aesthetic effects on the water such as poor colour. Similarly, the iron (1.935 mg/L), manganese (0.114 mg/L) and chloride (328.15 mg/L) will have aesthetic effects on the water such as poor taste and colour. Due to the elevated iron concentration, iron biofouling is likely to occur in the borehole if the borehole is not managed optimally. This will result in the clogging of the borehole as well as abstraction infrastructure. The groundwater from AB_BH1 is currently not suitable for human consumption without treatment. Should the water be used for irrigation, crop selection should take into account the elevated chloride concentration.

A number of chemical diagrams have been plotted for the groundwater sample and these are useful for chemical characterisation of the water and illustrate the similarities and differences in the water types. The Stiff Diagram is a graphical representation of the equivalent concentrations of the cations (positive ions) and anions (negative ions). This diagram shows concentrations of cations and anions relative to each other and direct reference can be made to specific salts in the water. From **Figure 8**, AB_BH1 is classified as a Sodium & Potassium/Chloride hydrofacies. This is expected of groundwater hosted in the greywacke and phyllites of the Tygerberg formation.




Figure 8: Stiff diagram of the groundwater sample.

The Sodium Adsorption Ratio (SAR) of the groundwater is plotted in **Figure 9**. AB_BH1 plots as S1/C3, thus classified as low risk in terms of sodium adsorption and high risk in terms of salinity hazard. This graph is typically applicable to irrigation, however, is dependent on soil texture and crop type.




Figure 9: SAR diagram of the groundwater sample.

4. RECOMMENDATIONS

Based on the information obtained from the yield test, the abstraction recommendation for the borehole is presented in **Table 7**. The yield testing was conducted with a Step Test, Constant Discharge Test and Recovery Test and while this data can be analysed to estimate sustainable yields, additional drilling in the area may result in long term cumulative impacts. Optimisation of the resource is also likely through making small changes to the abstraction rate, should the dynamic water level's drawdown be less or more than expected as per **Table 7**. Both of these points are best managed through long term monitoring data.

Table 7: Borehole Abstraction Recommendations

Borehole Details				
Borehole Name	Latitude (DD)	Longitude (DD)	Borehole Depth (m)	Inner Diameter (mm)
AB_BH1	-33.95713°	18.67164°	84	135

Abstraction Recommendations				
Borehole Name	Abstraction rate (L/s)	Abstraction Duration (hrs)	Recovery Duration (hrs)	Possible Volume Abstracted (L/d)
AB_BH1	2.9	24	0	250 560
Pump Installation Details				
Borehole Name	Pump Installation Depth (mbgl)	Critical Water Level (mbgl)	Dynamic Water Level (mbgl)*	Rest Water Level (mbgl)
AB_BH1	52	50	30	3.08

* Typical water level expected during long-term production

For borehole AB_BH1 it is recommended that abstraction can occur at a rate of up to 2.9 L/s for 12 hours per day. A pump suitable to deliver the recommended rate should be installed at a depth of 52 mbgl. It is anticipated that abstraction at the recommended rate will cause the water level to drop to a depth of approximately 30 mbgl – this is referred to as the dynamic water level. During abstraction, a maximum level cut off switch should be installed to 50 mbgl to ensure the groundwater level does not drop to the pump inlet.

From the laboratory results, groundwater from AB_BH1 is of poor quality for potable supply. The primary cause of the poor groundwater quality is the elevated turbidity (22.5 NTU). According to the SANS 241-1:2015 standards the elevated turbidity will have aesthetic effects on the water such as poor colour. Similarly, the iron (1.935 mg/L), manganese (0.114 mg/L) and chloride (328.15 mg/L) will have aesthetic effects on the water such as poor taste and colour. Due to the elevated iron concentration, iron biofouling is likely to occur in the borehole if the borehole is not managed optimally. This will result in the clogging of the borehole as well as abstraction infrastructure. The groundwater from AB_BH1 is currently not suitable for human consumption without treatment. Should the water be used for irrigation, crop selection should take into account the elevated chloride concentration.

To address the potential for iron to clog the borehole and abstraction infrastructure, it is recommended to maintain a constant and continuous pumping schedule as much as possible. Thus, should a daily volume of less than 250 560 L/d be required, it is recommended to decrease the pumping rate and not the pumping duration. By pumping continuously instead of on a stop-start schedule, iron oxidation in the borehole is minimized, decreasing the amount of iron precipitation inside the boreholes and pumps.

Through long term water level monitoring data, the abstraction volumes can be optimised by adjusting the abstraction rate if required. It is recommended that the borehole is equipped with a variable frequency drive. This enables adjustments to the flow rate to be made if required, as determined by the hydrogeological analysis of water level and flow rate monitoring data.

As of January 2018 the Department of Water and Sanitation released a Government Gazette stating that: “All water use sector groups and individuals taking water from any water resource (surface or groundwater) regardless of the authorization type, in the Berg, Olifants and Breede Gouritz Water

Management Area, shall install electronic water recording, monitoring or measuring devices to enable monitoring of abstractions, storage and use of water by existing lawful users and establish links with any monitoring or management system as well as keep records of the water used.”

Therefore, to facilitate monitoring and informed management of the borehole, it is highly recommended that the borehole be equipped with the following monitoring infrastructure and equipment (diagram included in **Appendix D**):





- Installation of a 32 mm (inner diameter, class 10) observation pipe from the pump depth to the surface, closed at the bottom and slotted for the bottom 5 – 10 m. This was done during the testing activities in November 2023.
- Installation of an electronic water level logger (for automated water level monitoring).
- Installation of a sampling tap (to monitor water quality).
- Installation of a flow volume meter (to monitor abstraction rates and volumes).

This monitoring data should be analysed by a qualified Hydrogeologist to ensure long-term sustainable use from the borehole. The legal compliance with regard to the use of the groundwater also needs to be addressed with the Department of Water and Sanitation.

5. REFERENCES

- Barker, J.A., (1988) A Generalised Radial Flow Model for Hydraulic Tests in Fractured Rock. *Water Resources Research*, Vol. 24, No. 10 Pages 1796 – 1804.
- Council for Geoscience (1984). The 1: 50 000 geological map series Map number: 3318 DC Bellville.
- DWAF (1998). Quality of domestic water supplies, Volume 1: Assessment guide. Department of Water Affairs and Forestry, Department of Health, Water Research Commission, 1998.
- Todd, D.K., (1980). *Groundwater Hydrology*, 2nd ed., John Wiley & Sons, New York, 535p.
- Meier, P.M., Carrera, J. & Sanchez-Vila, X (1998). An evaluation of Jacob’s method for the interpretation of pumping tests in heterogeneous formations. *Water Resources Research*, Vol. 34, No. 5. 1011 – 1025.
- National Water Act (1998). The National Water Act, No 36. Department of Water Affairs and Forestry. Pretoria.
- SANS (10299-4:2003). South African National Standard. Development, maintenance and management of groundwater resources. Part 4: Test-pumping of water boreholes. ISBN 0-626-14912-6.
- SANS (241-1:2015). Drinking water – Part 1: Microbiological, physical, aesthetic and chemical determinants.

6. APPENDIX A: BOREHOLE LOG

Log of Borehole No.: AB_BH1			
Location:	Blackheath	Latitude:	-33.95713
Date:	20-Nov-23	Longitude:	18.67164
Client:	kls Consulting	Ground Elevation:	46 mamsl
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Springfontyn fm. Sandy loam	 <p>0 10 20</p>		Water level (3.08 m) 219 mm Solid Steel casing (0 - 24 m)
Tygerberg fm. Clay and weatherd phyllites	 <p>30 40</p>		177 mm Solid Steel casing (0 - 48 m) 139 mm Solid Steel casing (0 - 48 m & 78 - 84 m)
Tygerberg fm. Phyllites	 <p>50 60 70 80</p>		139 mm Perforated Steel casing (48 - 78 m) Water strikes (54, 59, 70 and 77 m) EOH (84 m)
Drilled By:	Gerritsen Drilling SA	Remarks:	Blow yield 18 000 L/h
Drill Method:	Air Percussion		
Logged By:	S.Swart		



7. APPENDIX B: YIELD TEST DATA



Unit 12, Technostell
 9 Quantum Street, Technopark,
 Stellenbosch, 7600
 PO Box 12412, Die Boord,
 7613, South Africa
 Tel: +27 (0)21 880 1079
 Fax: +27 (0) 86 605 1121
 www.geoss.co.za

Borehole Yield Test Results

Project Name	Ackermans Blackheath
Project Number	5315_A
Borehole Name	AB_BH1

Site Details		
Province	Western Cape	
Area	Blackheath	
Farm/Site Name	Ackermans development	
Rig operator	Lusanda/Nunens	
Pump type	7.5 KW	
Coordinate system	-33.95713	Lat
	18.67164	Long
BoreholeStatus	Newly drilled	
Borehole depth	84	m
Borehole diameter (OD,ID)	135 ID	mm
Dummy pump test	*4	
Casing depth	78	m
Casing height	0.49	m
Datum level above ground	0.98	m
Test pump depth	78.12	m
Observation pipe depth	75.32	m
Logger depth	75.32	m
Available Drawdown	71.26	m
Water level before the test	3.49	mbch
Rest water level before step test	4.06	mbdl
	3.08	mbgl
Rest water level before CDT	4.95	mbdl
	3.97	mbgl
Outlet distance	Stormwater	m
Water sample type	Sans 241	
Comment	Completed	

Test date		
06-Nov-23	-	09-Nov-23

Step test details					
Date	Step	Length	Flow rate		Comments
06-Nov-23	1	1 h	1.0	l/s	Completed
06-Nov-23	2	1 h	2.5	l/s	Completed
06-Nov-23	3	1 h	4.0	l/s	Completed
06-Nov-23	4	1 h	4.8	l/s	Completed

Constant discharge test details				
Start Date	Length	Flow rate		Comments
07-Nov-23	24	4.6	l/s	Completed

Recovery details	
Start Date	Data Capture
08-Nov-23	Solinst logger

Monitoring boreholes			
Borehole:	RWL	Distance from:	AB_BH1

GEOS SOUTH AFRICA (PTY) LTD • REG NO 2018/636989/07

DIRECTORS: JE CONRAD, DL BARROW

Step Test	06-Nov-23	5315_A	AB_BH1
Time	14:00	RWL (mbgl)	3.08
Ackermans Blackheath			
Step 1		Step 2	
1 l/s		2.5 l/s	
Time interval (min)	Water level drawdown (m)	Time interval (min)	Water level drawdown (m)
1	0.16	61	2.96
2	0.72	62	3.86
3	1.05	63	4.17
5	1.20	65	4.46
7	1.23	67	4.60
10	1.30	70	4.80
15	1.41	75	4.99
20	1.49	80	5.16
30	1.64	90	5.44
40	1.75	100	5.68
50	1.85	110	5.87
60	2.04	120	6.03
Step 3		Step 4	
4 l/s		4.8 l/s	
121	7.61	181	13.52
122	9.02	182	14.15
123	9.44	183	14.43
125	9.82	185	14.72
127	10.06	187	14.91
130	10.32	190	15.12
135	10.64	195	15.39
140	10.89	200	15.62
150	11.29	210	16.01
160	11.62	220	16.36
170	11.93	230	16.66
180	12.22	240	17.08

Constant Discharge Test (CDT) - Raw data			
Ackermans Blackheath			
5315_A	AB_BH1	07-Nov-23	
Time:	06:59	RWL (mbgl)	3.97
Abstraction rate (L/s)			4.6
Test Duration: 24 hours			
Hours	Time interval (min)	Water level drawdown (m)	
	0	0.00	
	1	0.00	
	2	0.07	
	3	0.97	
	4	2.51	
	5	3.01	
	6	7.26	
	7	8.57	
	8	9.15	
	9	9.51	
	10	9.78	
	12	10.20	
	15	10.68	
	20	11.22	
	25	11.67	
	30	11.98	
	40	12.58	
	50	13.07	
1	60	13.52	
	70	13.92	
	80	14.27	
	90	14.59	
	100	14.89	
2	120	15.42	
	150	16.26	
3	180	16.79	
4	240	17.78	
5	300	18.55	
6	360	19.25	
8	480	20.31	
10	600	21.04	
12	720	21.63	
14	840	22.10	
16	960	22.49	
18	1080	22.82	
20	1200	23.11	
22	1320	23.35	
24	1440	23.60	

Post CDT Recovery		
Ackermans Blackheath		
5315_A	AB_BH1	08-Nov-23
Hours	Time interval (min)	Water level drawdown (m)
	0	23.60
	1	23.23
	2	15.48
	3	14.29
	4	13.73
	5	13.35
	6	13.06
	7	12.82
	8	12.60
	9	12.42
	10	12.26
	12	11.99
	15	11.64
	20	11.16
	25	10.79
	30	10.46
	40	9.93
	50	9.49
1	60	9.11
	70	8.77
	80	8.46
	90	8.19
	100	7.93
2	120	7.48
	150	6.91
3	180	6.43
4	240	5.66
5	300	5.05
6	360	4.54
8	480	3.73
10	600	3.12
12	720	2.64
14	840	2.24
16	960	1.91
18	1080	1.63
20	1200	1.38
22	1320	1.18
24	1440	0.99

8. APPENDIX C: WATER QUALITY



TEST REPORT

Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2023-11-14

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling
P.O.Box 12412
Dia Boord, Stellenbosch
7613
+27218801079



Sample Details	
SampleID	W44210
Water Type	Drinking Water
Water Source	Borehole
Sample Temperature	
Description	5315_A_AB_BH1
Batch Number	5315_A_AB_BH1
PO Number	5315_A_AB_BH1
Date Received	2023-11-10
Condition	Good

Water - Routine									
	Unit	Method	Uncertainty	Limit	Results	Results	Results	Results	Results
pH@ 25C (Water)		VDN-05-MFW01	^^^	>= 5 to <= 9.7	7.11				
Conductivity@ 25C (Water)	mS/cm	VDN-05-MFW02	^	<= 170	136.1				
Turbidity (Water)†	ntu			<= 5	22.5				
Total dissolved solids (Water)†	mg/L			<= 1200	922.76				
Free Chlorine (Water)†	mg/L			<= 5	<0.02				
Ammonia (NH4) as N (Water)	mg/L	VDN-05-MFW08	8.00%	<= 1.5	0.19				
Nitrate as N (Water)	mg/L	VDN-05-MFW08	11.00%	<= 11	<1.00				
Nitrite as N (Water)	mg/L	VDN-05-MFW08	4.50%	<= 0.9	<0.05				
Chloride (Cl-) - Water	mg/L	VDN-05-MFW08	10.12%	<= 300	328.15				
Sulphates (SO4) - Water	mg/L	VDN-05-MFW08	7.56%	<= 500	7.66				
Fluoride (F) - Water	mg/L	VDN-05-MFW08	12.30%	<= 1.5	<0.15				
Alkalinity as CaCO3 (Water)†	mg/L				173.20				
Colour (Water)†	mg/L Pt-Co			<= 15	<15				
Total Organic Carbon (Water)†	mg/L			<=10	0.54				
Date Tested					2023-11-10				

Water - Metals									
	Unit	Method	Uncertainty	Limit	Results	Results	Results	Results	Results
Calcium (Ca) - Water	mg/L	VDN-05-MFW43	14.00%		50				

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab. Vinlab is not liable to any client for any loss or damage suffered which could, directly or indirectly, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: P/F pyrometric, (Wineanalysis), Alcoholmeter, W = (Wineanalysis). Micro results: Enumeration of yeast, W, culture, 2 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO2 additions less than 10 days may depress the growth of microbes in culture although they are viable active in the wine. Some microbes, especially bacteria, may not grow in culture even when viable-potentially active in the wine.

† - Conductivity = 1000µS/cm = 1mS/m, = 1000µS/m = 1mS/m
 ** - COD, LR = 116mg/L, MR = 48mg/L, HR = 1477mg/L
 *** - pH ± 0.1

Doc No
V47005

VIN 00-01 30-11-2022

Page: 1 of 3

Visit Vinlab H2O



T0885



Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2023-11-14

TEST REPORT

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling
P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079



@VinlabSA

Magnesium (Mg) - Water	mg/L	VIN-05-MFW/43	8.40%		29			
Sodium (Na) - Water	mg/L	VIN-05-MFW/43	11.45%	<= 200	177			
Potassium (K) - Water	mg/L	VIN-05-MFW/43	9.42%		3			
Zinc (Zn) - Water	mg/L	VIN-05-MFW/43	19.40%	<= 5	<0.008			
Antimony (Sb) - Water†	µg/L			<=20	<13.0			
Arsenic (As) - Water†	µg/L			<= 10	<10.0			
Boron (B) - Water	µg/L	VIN-05-MFW/43	11.79%	<= 2400	54			
Cadmium (Cd) - Water	µg/L	VIN-05-MFW/43	12.20%	<= 3	1			
Chromium (Cr) - Water	µg/L	VIN-05-MFW/43	13.03%	<= 30	<4			
Copper (Cu) - Water	µg/L	VIN-05-MFW/43	11.57%	<= 2000	10			
Iron (Fe) - Water	µg/L	VIN-05-MFW/43	12.40%	<= 2000	1935			
Lead (Pb) - Water	µg/L	VIN-05-MFW/43	16.32%	<= 10	9			
Manganese (Mn) - Water	µg/L	VIN-05-MFW/43	12.44%	<= 400	114			
Nickel (Ni) - Water	µg/L	VIN-05-MFW/43	17.38%	<= 70	<8			
Selenium (Se) - Water†	µg/L			<= 40	<10.0			
Aluminium (Al) - Water	µg/L	VIN-05-MFW/43	13.40%	<= 300	<8			
Cyanide (CN) - Water†	µg/L			<= 200	<10.0			
Mercury (Hg) - Water†	µg/L			<= 6	<1.0			
Barium (Ba) - Water	µg/L	VIN-05-MFW/43	14.00%	<= 700	78			
Uranium (U) - Water†	µg/L			<= 30	<28			
Date Tested					2023-11-13			

Comments

W44210
Ion balance = 1.5%

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MV12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab. Vinlab is not liable to any client for any loss or damage suffered which could, directly or indirectly, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Py-F pyrometer, WinScan, Alcolyser, W • WinScan. Micro results: Enumeration of yeast: WL, nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at boiling. SO2 addition less than 10 days may deprive the growth of microbes in culture although they are viable/active in the wine. Some microbes, especially *Bacteroides*, may not grow in culture even when viable/potentially active in the wine.

* - Conductivity <1000µS/m = 1µmS/m, >1000µS/m = 1mS/m
** - CO₂, LR = 116mg/L, MR = 148mg/L, HR = 177mg/L
*** - pH ± 0.1

Doc No
V47605

VIN 09-01 30-11-2022

Page: 2 of 3

Visit Vinlab H2O





Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2023-11-14

TEST REPORT

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling
P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079



@VinlabSA

Caitlyn McCartney
Laboratory Manager - RP
VIN-05-
M01, M02, M03, M04, M05, M06, M07, M08,
M09, M10, M11, M12, M13, M14, M15,
M16, M17, M18, M19, M20, M21, M22,
M23, M24, M25, M26, M27, M28, M29,
M30, M31, M32, M33, M34, M35, M36,
M37, M38, M39, M40, M41, M42, M43,
M44, M45, M46, M47, M48, M49, M50,
M51, M52, M53, M54, M55, M56, M57, M58, M59

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MV12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab. Vinlab is not liable to any client for any loss or damage suffered which could, directly or indirectly, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: P₁-pyrometer; W=weascan; A=alcolyser; W=Weascan. Micro results: Enumeration of yeast: WL, nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. GC2 additions less than 10 days may depress the growth of microbes in culture although they are viable/active in the wine. Some microbes, especially *bactobacilli*, may not grow in culture even when viable/potentially active in the wine.

* - Conductivity = 1000µS/m • 1mS/m, >1000µS/m • 1µS/m
** - COD, LR = 15mg/L, MR = 240mg/L, IR = 1477mg/L
*** - pH ± 0.1



Doc No
V47005


VIN 00-01 30-11-2022


Page: 3 of 3

Visit Vinlab H2O

T0885


9. APPENDIX D: MONITORING INFRASTRUCTURE DIAGRAM





10. APPENDIX E: YIELD TEST DATA ANALYSIS

AB_BH1




FC - Non Linear Method to estimate Q Sust

skin effect	Non-Darcian loss		Darcian loss		
A	C	p	B	n	e
7.00E-06	0.00E+00	2.00E+00	2.00E-03	1.87E+00	1.37E+00

Extrapolation	
Ext. pol time (min)	1051200
Q (L/s)	4.8
Drawdown (m)	50.10

Available drawdown (m) =	50		
No boundaries	1 no-flow	2 no-flow	Closed
4.8	2.4	1.6	0.8
Q Sust (L/s) =	2.40	std. dev =	1.73

Boundaries selected	0 - closed
---------------------	------------




Cooper-Jacob method

T (m ² /d) =	11.4	r _e (m) =	0.1
S =	4.98E-01	Q (l/s) =	4.60

No boundaries	1 no-flow	2 no-flow	Closed
Q_sust	5.46	2.73	1.80
Avg. Q_sust =	2.84	std. dev =	1.84

Boundaries selected	0 - closed
---------------------	------------




FC method

Extrapolation time in years	2	1051200	Extrapol time in minutes	
Effective borehole radius (r _e)	0.57280349	0.572803489	Est. r _e	From (r _e) sheet
Q (l/s) from pumping test	4.6	0.066104112	S-late	Change r _e
s _a (available drawdown), sigma_s	50	0	Sigma_s	from risk
Annual effective recharge (mm)	0	50	s _{available}	w orking draw down n(m)
t(end) and s(end) of pumping test	1440	23.6004	End time and draw down	n of test
Average maximum derivative	6.44	8.235796315	Estimate of average of max deriv	
Average second derivative	0.08	-0.04336762	Estimate of average second deriv	
Derivative at radial flow period	10.7186651	10.71866508	Read from derivative graph	
T-early (m ² /d)	6.785501687	Aqui. thick (m)	60	
T and S estimates	T-late [m ² /d]	11.29371429	Est. S-late	0.0033
	S-late	0.066104112		

BASIC SOLUTION

sWell (Extrapol time) =	No boundaries	1 no-flow	2 no-flow	Closed no-flow
Q_sust (l/s) =	42.37	60.81	79.25	134.57
Average Q_sust (l/s) =	5.43	3.78	2.90	1.71
w/ standard deviation =	1.57			

Boundaries selected	0 - closed
---------------------	------------




Barker method

Fit Parameters	K _v [m/d]	S ₁ [1/m]	b	n	N
	0.20	1.41E-03	48.67	1.91	0.0450

No boundaries	1 no-flow	2 no-flow	Closed	
sWell (Extrapol time)	48.26	85.14	103.58	122.02
Q_sust	4.77	2.70	2.22	1.88

Fractal n =	1.91	Average Q-sust (l/s) =	2.89	std. dev =	1.29
-------------	------	------------------------	------	------------	------

Boundaries selected	0 - closed
---------------------	------------



Recovery

T (m ² /d)	12.25523953
CDT Duration	1440
Recovery Duration	1440
Max % Recovery	95.8

(LAST PAGE)