



Borehole Yield and Quality Testing at Elgin Free Range Chickens Agri Operations, Lottershof Farm, Caledon

Prepared by
GEOSS
15 August 2024



Executive Summary

GEOSS South Africa (Pty) Ltd was appointed by Willie Benson from Elgin Free Range Chickens Agri Operations to conduct yield and groundwater quality testing of one borehole at Lottershof farm, Caledon. The yield testing was undertaken by ATS under the management and supervision of GEOSS SA from the 30th of July to the 3rd of August 2024. This included a Step Test, CDT and Recovery Test at the borehole and sampling of the groundwater for chemical analysis. It is recommended that groundwater abstraction occur within the below-mentioned parameters from the tested borehole. Aquifer over-abstraction is unlikely to occur if these rates are adhered to and if the borehole is managed through long-term monitoring data.

Borehole Details				
Borehole Name	Latitude (DD, WGS84)	Longitude (DD, WGS84)	Borehole Depth (m)	Inner Diameter (mm)
ECA_BH1	-34.30790°	19.47264°	138.6	177
Abstraction Recommendations				
Borehole Name	Abstraction rate (L/s)	Abstraction Duration (hrs)	Recovery Duration (hrs)	Possible Volume Abstracted (L/d)
ECA_BH1	1.5	24	0	129 600
Pump Installation Details				
Borehole Name	Pump Installation Depth (mbgl)	Critical Water Level (mbgl)	Dynamic Water Level (mbgl)*	Rest Water Level (mbgl)
ECA_BH1	66	63	29	8.23

* Typical water level expected during long-term production

Through long term water level monitoring data, the abstraction volumes can be optimised by adjusting the abstraction rate, if required. It is recommended that the borehole is equipped with a variable frequency drive. This enables adjustments to the flow rate to be made if required, as determined by the hydrogeological analysis of water level and flow rate monitoring data.

From the laboratory results, groundwater from ECA_BH1 is of poor quality for potable use. The primary issue is elevated turbidity, measured at 27.3 NTU, which exceeds the SANS 241-1:2015 aesthetic standard. This level of turbidity is likely due to fine sediments entering the borehole, and it causes aesthetic issues such as cloudiness in the water. Although some of the turbidity may clear up during borehole development, the presence of elevated iron (0.549 mg/L) poses additional concerns. High iron levels can lead to aesthetic problems like red staining on walls and infrastructure, and they increase the risk of iron biofouling. If not managed properly, biofouling could clog the borehole and associated abstraction infrastructure.

To address the potential for iron to clog the borehole and abstraction infrastructure, it is recommended to maintain a constant and continuous pumping schedule as much as possible. Thus, should a daily volume of less than 129 600 L/d be required, it is recommended to decrease the pumping rate and not the pumping duration. By pumping continuously instead of on a stop-start schedule, iron oxidation in the borehole is minimized, decreasing the amount of iron precipitation inside the boreholes and pumps.

To facilitate monitoring and informed management of the borehole, it is recommended to equip borehole with the following monitoring infrastructure and equipment:

- Installation of a 32 mm (inner diameter, class 10) observation pipe from the pump depth to the surface, closed at the bottom and slotted for the bottom 5 – 10 m.
- Installation of an electronic water level logger (for automated water level monitoring)
- Installation of a sampling tap (to monitor water quality)
- Installation of a flow volume meter (to monitor abstraction rates and volumes)

This report is an important document for obtaining the legal compliance with regard to the use of the groundwater with the Department of Water and Sanitation, but does not constitute a Geohydrological Assessment report in support of a WULA, which would need to incorporate information from this report.

Client Information:

Prepared for	Elgin Free Range Chickens Agri Operations
Contact Person	Willie Benson
Contact Email	willieb@efrc.co.za
Contact Number	072 587 4537



Author Information:

Prepared by	GEOSS South Africa (Pty) Ltd Unit 12, Technostell Building 9 Quantum Street TechnoPark Stellenbosch 7600
Contact Email	info@geoss.co.za
Contact Number	(021) 880 1079

Document Information and History:

Report Name	Borehole Yield and Quality Testing at Elgin Free Range Chickens Agri Operations, Lottershof Farm, Caledon		
Report No	2024/08-19		
Suggested Citation	GEOSS (2024). Borehole Yield and Quality Testing at Elgin Free Range Chickens Agri Operations, Lottershof Farm, Caledon. GEOSS Report Number: 2024/08-19. GEOSS – South Africa (Pty) Ltd. Stellenbosch, South Africa.		
GEOSS Project Number	2019_06-3569_L		
Cover Photo	Cover photo taken during yield testing		
Issue	Version	Date	Reviewed by
1	1.0	15 August 2024	Ashleigh Lakshuman

Principal Author(s) and Reviewer(s):

	Principal Author	Principal Reviewer
		
Name	Reuben Lazarus	Ashleigh Lakshuman
Qualification	MSc (Geology – Environmental Geochemistry)	MSc (Environmental and Water Science)
SACNASP No.	120711	131887
Registration	Earth Science (Pr.Sci.Nat)	Earth Science (Can.Sci.Nat)

This report (including any enclosures and attachments) has been prepared for the exclusive use and benefit of Elgin Free Range Chickens Agri Operations, and solely for the purpose for which it is provided. Unless we provide express prior written consent, no part of this report should be reproduced, distributed or communicated to any third party. We do not accept any liability if this report is used for an alternative purpose from which it is intended, nor to any third party in respect of this report.

Table of Contents

Executive Summary	ii
1 Introduction	1
2 Yield Testing	1
2.1 Methodology	1
2.2 Yield Testing at AB_BH1	4
3 Water Quality Analysis	8
4 Recommendations	13
5 References	15
6 Appendix A: Borehole Log	16
7 Appendix B: Yield Test Data	18
8 Appendix C: Water Quality	23
9 Appendix D: Monitoring Infrastructure Diagram	26
10 Appendix E: Yield Test Data Analysis	29

List of Tables

Table 1: Borehole Details	1
Table 2: Yield Determination - ECA_BH1	7
Table 3: Classification table for the specific limits.	8
Table 4: Classification table for the groundwater results (DWAF, 1998).	9
Table 5: Production borehole results classified according to SANS241-1:2015.	10
Table 6: Classified production borehole results according to DWAF 1998.	11
Table 7: Borehole Abstraction Recommendations.	13

List of Figures

Figure 1: ECA_BH1 during (left) and after (right) testing.	1
Figure 2: Step Test drawdown data for ECA_BH1.	5
Figure 3: Semi-Log Plot of drawdown during the CDT of ECA_BH1 (CDT 1: 15 L/s, CDT 2: 12.5 L/s).	6
Figure 4: Time-series drawdown and recovery for ECA_BH1 (CDT 1: 15 L/s, CDT 2: 12.5 L/s).	6
Figure 5: Radius of influence for ECA_BH1 at the recommended sustainable yield (1.5 L/s).	8
Figure 6: Stiff diagram of the groundwater sample (ECA_BH1).	12
Figure 7: SAR diagram of the groundwater sample (ECA_BH1).	12

List of Maps

Map 1: Borehole Locality Map.	2
Map 2: Geological Map with Property Boundary and Tested Borehole Position (1:250 000 Geological Map Series, 3319 Worcester) (CGS, 1997).	3

Abbreviations

AD	Available Drawdown
bh	Borehole
CDT	Constant Discharge Test
CGS	Council for Geoscience
DD	Decimal degree
DWA	Department of Water Affairs (pre- 1994)
DWAF	Department of Water Affairs and Forestry (1994 – 2009)
DWS	Department of Water and Sanitation (2009 –)
EC	Electrical Conductivity
FC	Flow Characteristic
GRF	Generalised Radial Flow
IARF	Infinite Acting Radial Flow
ID	inner diameter
L/d	litres per day
L/s	litres per second
m	metres
m ² /d	meters squared per day
mamsl	metres above mean sea level
mbch	metres below collar height
mbgl	metres below ground level
mg	milligram
mg/L	milligram per litre
mm	millimetres
nd	not detected
OD	outer diameter
RWL	rest water level below ground level
SANS	South African National Standard
T	Transmissivity
TDS	total dissolved solids
WGS84	Since the 1st January 1999, the official co-ordinate system for South Africa is based on the World Geodetic System 1984 ellipsoid, commonly known as WGS84
WL	water level
WULA	Water Use Licence Assessment

Glossary of Terms

aquifer	a geological formation, which has structures or textures that hold water or permit appreciable water movement through them [from National Water Act (Act No. 36 of 1998)].
available drawdown	available drawdown in a borehole is the difference between the rest water level or piezometric surface and the depth that the water level may drop to (typically major water bearing unit, boundary inflection or pump depth).
borehole	includes a well, excavation, or any other artificially constructed or improved groundwater cavity which can be used for the purpose of intercepting, collecting or storing water from an aquifer; observing or collecting data and information on water in an aquifer; or recharging an aquifer [from National Water Act (Act No. 36 of 1998)].
confined aquifer	an aquifer confined between two impermeable beds
dynamic water level	the stabilised water level in the borehole during production over long periods of time.
electrical conductivity	the ability of groundwater to conduct electrical current, due to the presence of charged ionic species in solution (Freeze and Cherry, 1979).
fractured aquifer	Fissured and fractured bedrock resulting from decompression and/or tectonic action. Groundwater occurs predominantly within fissures and fractures.
groundwater	Water found in the subsurface in the saturated zone below the water table or piezometric surface i.e., the water table marks the upper surface of groundwater systems.
intergranular aquifer	an aquifer in which groundwater is stored in and flows through open pore spaces in the unconsolidated Quaternary deposits.
rest water level	the groundwater level in a borehole not influenced by abstraction or artificial recharge.
sustainable yield	sustainable yield is defined as the rate of withdrawal that can be sustained by an aquifer without causing an unacceptable decline in the hydraulic head or deterioration in water quality in the aquifer.
transmissivity	the rate at which water is transmitted through a unit width of an aquifer under a unit hydraulic gradient.
unconfined aquifer	an aquifer which has free water surface - which means the water table exists for this type of aquifer; primarily recharged by the infiltration of precipitation from the ground surface

SPECIALIST EXPERTISE

CURRICULUM VITAE – Reuben Lazarus

GENERAL

Nationality: South African
Profession: Hydrogeologist
Specialization: Groundwater development, yield testing, geochemistry and camera logging
Position in firm: Hydrogeologist, Business Unit Leader: Yield and Water Quality Testing at GEOSS South Africa (Pty) Ltd
Date commenced: October 2017
Year of birth & ID #: 1992 – 9207075195083
Language skills: Afrikaans (mother tongue) English (excellent)

KEY SKILLS

- Groundwater component of Catchment Management Strategies and other Groundwater Resource Directed Measures.
- Groundwater development – borehole drilling and test pumping supervision and analysis.
- Groundwater monitoring – development and analysis of groundwater level and quality data.
- Groundwater management – sustainable aquifer development and management.
- Groundwater contamination assessments – geochemical analysis.
- Writing of hydrogeological reports
- ArcMap / Geochemist's Workbench / WISH and typical software skills.

EDUCATIONAL AND PROFESSIONAL STATUS

Qualifications

2018	BSc (Geology – Environmental Geochemistry)	University of Stellenbosch, South Africa
2016	BSc (Hons) (Earth Science)	University of Stellenbosch, South Africa
2015	BSc (Earth Science)	University of Stellenbosch, South Africa

Courses and symposiums

2023	VFD Level 1 and Level 2 (ElectroMechanica)
2023	PLC Level 1 and Level 2 AS 200 (ElectroMechanica)
2023	Basic hydraulics & Pumps (Dudley Willer)
2022	Environmental Sampling Workshop (Van Walt)
2019	SA remediation workshop (Enviro Workshops)

Memberships/Organisations

- South African Council for National Scientific Professions (SACNASP)- Mem. No. Pr.Sci.Nat: 120711
- Groundwater Division of the Geological Society of South Africa UID 9661/21
- Geological Society of South Africa Mem. No. 970021

EMPLOYMENT RECORD

June 2021 – present:	GEOSS South Africa (Pty) Ltd, Stellenbosch <i>Project Hydrogeologist: Yield and Water Quality Testing Business Unit Leader</i>
October 2018 – June 2021:	GEOSS South Africa (Pty) Ltd, Stellenbosch <i>Project Hydrogeologist</i>
October 2017 – October 2018:	GEOSS - Geohydrological and Spatial Solutions International (Pty) Ltd <i>Student Hydrogeologist</i>

SPECIALIST DECLARATION

I, Reuben Lazarus, as the appointed independent specialist(s) hereby declare that we:

- act/ed as the independent specialist in this application;
- regard the information contained in this report as it relates to our specialist input/study to be true and correct, and
- do not have and will not have any financial interest in the undertaking of the activity, other than remuneration for work performed in terms of the South African National Standard (SANS 10299-4:2003, Part 4 – Test pumping of water boreholes);
- have and will not have no vested interest in the proposed activity proceeding;
- have provided the competent authority with access to all information at my disposal regarding the application, whether such information is favourable to the applicant or not



Reuben Lazarus
GEOSS South Africa (Pty) Ltd
SACNSAP – Pr.Sci.Nat:
15 August 2024

1 Introduction

GEOSS South Africa (Pty) Ltd was appointed by Willie Benson from Elgin Free Range Chickens Agri Operations to conduct yield and water quality testing of one borehole at Lottershof farm, Caledon.

The borehole was tested by ATS under the management and supervision of GEOSS SA from the 30th of July to the 3rd of August 2024, details of this are presented in this report. The borehole's details are presented in **Table 1** below and spatially in **Map 1**. A borehole drill log is presented in **Appendix A**. The geological setting of the area indicates that the borehole is drilled through the sandstone of the Rietvlei formation (**Map 2**).

Table 1: Borehole Details.

Borehole	Latitude (DD, WGS84)	Longitude (DD, WGS84)	Depth (m)
ECA_BH1	-34.30790°	19.47264°	138.6



Figure 1: ECA_BH1 during (left) and after (right) testing.

2 Yield Testing


2.1 Methodology

The yield testing was undertaken by ATS under the management and supervision of GEOSS SA from the 30th of July to the 3rd of August 2024 and carried out according to the National Standard (SANS 10299-4:2003, Part 4 – Test pumping of water boreholes). This included a Step Test, Constant Discharge Test (CDT) and recovery monitoring of the borehole. For the Step Test, a borehole is pumped at a constant rate for one-hour intervals and the flow rates are incrementally increased for each step. This test is followed by a Constant Discharge Test where the borehole is pumped at a constant rate for an extended period of time, followed by recovery monitoring. The water level drawdown is monitored at pre-determined intervals during these tests (drawdown refers to the difference in water level from the rest water level (RWL) measured before commencement of the yield test). Raw data and measurements taken during the yield tests are presented in **Appendix B**.

Borehole Yield and Quality Testing at Elgin Free Range Chickens Agri Operations, Lottershof Farm, Caledon



Map 1: Borehole Locality Map.



Map 2: Geological Map with Property Boundary and Tested Borehole Position (1:250 000 Geological Map Series, 3319 Worcester) (CGS, 1997).

The yield test data was analysed using the excel-based FC program, developed by the IGS (Institute for Groundwater Studies) in Bloemfontein. The sustainable yield of the borehole was calculated based upon long-term extrapolations of the CDT data according to (1) the Cooper-Jacob approximation of the Theis solution for confined aquifers, (2) the Barker Generalised Radial Flow Model (GRF) for hydraulic tests in fractured rock and (3) the Flow Characteristic (FC) method(s) using first and second derivative calculations. Boundary conditions are accounted for in multiplication factors to the rate of drawdown (derivatives), according to each of the above three methods. These three methods are briefly described below.

1. The Cooper-Jacob approximation of the Theis solution for confined aquifers was designed for porous media aquifers, where infinite acting radial flow (IARF) was observed during the pumping of a borehole. The application of this method to fractured aquifers was discussed by Meier et al (1998), concluding that T estimates using the Cooper-Jacob analysis gave an effective T for the fracture zone. The Cooper-Jacob analysis (and more accurately the Theis method) is therefore viable for analysing pumping test data for fractured aquifers where IARF is observed. The parameters are then used to predict theoretical long-term drawdowns.
2. The Barker GRF Model (Barker, 1988) uses fracture hydraulic conductivity, fracture storativity and flow domain to predict drawdown due to abstraction in a borehole in a fractured medium. By changing these values, a curve of drawdown predictions can be made to fit real-world data and therefore predict theoretical long-term drawdowns.
3. The FC methods are the Basic FC, the FC Inflection Point and the FC Non-Linear. The Basic FC and the FC Inflection Point methods make use of the derivatives of the drawdown data to predict theoretical long-term drawdowns and the scale-back factors are applied to selected available drawdowns. The FC Non-Linear method uses curve fitting of the Step Test data to predict theoretical long-term drawdowns. Due to the short nature of the Step Test, this method is usually not included if the other methods of analysis differ from it.

In all three methods, the available drawdown was carefully selected to ensure that the flow regime described by the analytical solution is not extrapolated beyond its applicable depth, which may easily result in an overuse of the resource. For ECA_BH1 this was 54 m (63 mbgl), based on an inflection point observed in the test data corresponding to a fracture observed during drilling. A two-year extrapolation time without recharge to the aquifer was selected as per the recommendations within the FC method program.

Water samples were collected at the end of the yield test and submitted for inorganic chemical analyses.

2.2 Yield Testing at AB_BH1

The yield testing was conducted between the 30th of July and the 3rd of August 2024. The borehole was measured to a depth of 138.6 meters below ground level (mbgl). The test pump was installed at a depth of 118.5 mbgl. The rest water level (RWL) at the start of the test was 8.23 mbgl.

During the step test, the water level was drawn down 83.86 meters below the rest water level (92.8 mbgl) during the 4th step at a rate of 25 L/s. 10 minutes into the final step the pump broke down due to sand ingress. **Figure 2** shows the time-series drawdown for the Step Test.




Figure 2: Step Test drawdown data for ECA_BH1.

The water level was left to recover overnight. Before starting the CDT, the water level recovered to 8.57 mbgl. Based on the results of the Step Test, the planned 24-hour CDT was conducted at a rate of 15 L/s (54 000 L/hour). After 17.7 hours, the water level had drawn down 109.12 meters below the rest water level (pump inlet). The borehole was left to recover to 12.98 mbgl, before starting a second CDT for the remaining 7 hours at 12.5 L/s. After the 7 hours, the water level had drawn down to 52.7 meters below the rest water level to 66.39 mbgl.

The semi-log plot of the drawdown from the CDT is presented in **Figure 3**. The available drawdown (AD) is indicated with the horizontal red line at 54 m.




Figure 3: Semi-Log Plot of drawdown during the CDT of ECA_BH1 (CDT 1: 15 L/s, CDT 2: 12.5 L/s).

The recovery of the water level was monitored after the first CDT and is presented in **Figure 4**. The recovery was moderate, reaching 93.6% after pump time and 95.8% in 24 hours. Monitoring will be essential to determine the long-term recovery of the borehole.




Figure 4: Time-series drawdown and recovery for ECA_BH1 (CDT 1: 15 L/s, CDT 2: 12.5 L/s).

Several methods were used to assess the yield test data as presented in **Table 2**. It is recommended that the borehole can be abstracted from at a rate of up to 1.5 L/s (5 400 L/hour) for up to 24 hours per day. The assessments were based on an available drawdown (AD) of 54 meters below the RWL of the CDT, which equates to 63 mbgl.

Table 2: Yield Determination - ECA_BH1.

ECA_BH1			
Method	Sustainable Yield (L/s)	Late *T (m ² /d)	*AD used (m)
Basic FC	1.88	5.8	54.0
FC inflection point	1.89		58.0
Cooper-Jacob	2.19	6.1	54.0
FC Non-Linear	0.71	3	54.0
Barker	0.79		54.0
Average Q_sust (L/s)	1.49		
Recommended Abstraction			
Abstraction Rate (L/s)	Abstraction Duration (hours)	Recovery Duration (hours)	
1.5	24	0	

**AD- Available Drawdown

* T – Transmissivity

No boreholes were monitored during the testing of ECA_BH1. Transmissivity was calculated through the Theis method using the drawdown response in ECA_BH1. The transmissivity of the system was calculated at 6.1 m²/d. A storativity value of 5×10^{-4} was used for the radius of influence calculation based on an average expected value of confined aquifers as report by (Todd, 1980). Based on the aquifer parameters the radius of influence was calculated for the recommended sustainable yield of the borehole. A drawdown of up to 5 meters can be expected 1 kilometre away from ECA_BH1 at the recommended sustainable rate (1.5 L/s for 24 hours per day) after 2 years of abstraction without recharge (**Figure 5**).

It must be noted that the Cooper-Jacob modelling of radius of influence is based on a homogenous, confined aquifer and therefore does not account for the heterogeneity associated with secondary aquifers (fractured rock). Thus, the radius of influence model will only provide an indication of how abstraction at AB_BH1 will impact the water level in the fracture network. This suggests that the cone of depression will not expand equivalently in all directions surrounding the borehole, but will rather propagate along the fracture network within the secondary aquifer.




Figure 5: Radius of influence for ECA_BH1 at the recommended sustainable yield (1.5 L/s).

3 Water Quality Analysis

Groundwater samples were collected from the borehole at the end of the yield test and submitted for inorganic chemical analyses to a SANAS accredited laboratory (Vinlab) in the Western Cape. The certificate of analysis for the sample is presented in **Appendix C**. The chemistry results obtained for the borehole have been classified according to the SANS241-1: 2015 standards for domestic water (**Table 3**). **Table 5** presents the water chemistry analysis results, colour coded according to the SANS241-1: 2015 drinking water assessment standards.

Table 3: Classification table for the specific limits.

Acute Health	Aesthetic	Chronic Health	Operational	Acceptable
--------------	-----------	----------------	-------------	------------

The limits and associated risks for domestic water as determined by the South African National Standard (SANS) 241:2015 are as follows, where:

- Health risks: parameters falling outside these limits may cause acute or chronic health problems in individuals.
- Aesthetic risks: parameters falling outside these limits indicate that water is visually, aromatically or palatably unacceptable.
- Operational risks: parameters falling outside these limits may indicate that operational procedures to ensure water quality standards are met may have failed.

The chemistry results obtained have also been classified according to the DWAF (1998) standards for domestic water. **Table 4** enables an evaluation of the water quality with regards to the various parameters measured (DWAF, 1998). **Table 6** presents the water chemistry analysis results colour coded according to the DWAF drinking water assessment standards.

Table 4: Classification table for the groundwater results (DWAF, 1998).

Class	Water quality	Description
Class 0	Ideal	Suitable for lifetime use.
Class I	Good	Suitable for use, rare instances of negative effects.
Class II	Marginal	Conditionally acceptable. Negative effects may occur.
Class III	Poor	Unsuitable for use without treatment. Chronic effects may occur.
Class IV	Dangerous	Totally unsuitable for use. Acute effects may occur.

From the chemical results presented in **Table 5** and **Table 6**, groundwater from ECA_BH1 is of poor quality for potable use. The primary issue is elevated turbidity, measured at 27.3 NTU, which exceeds the SANS 241-1:2015 aesthetic standard. This level of turbidity is likely due to fine sediments entering the borehole, and it causes aesthetic issues such as cloudiness in the water. Although some of the turbidity may clear up during borehole development, the presence of elevated iron (0.549 mg/L) poses additional concerns. High iron levels can lead to aesthetic problems like red staining on walls and infrastructure, and they increase the risk of iron biofouling. If not managed properly, biofouling could clog the borehole and associated abstraction infrastructure.

Table 5: Production borehole results classified according to SANS241-1:2015.

Analyses	ECA_BH1	SANS 241-1:2015
Date and Time Sampled	03/09/2024 15:00	
pH (at 25 °C)	6.0	5.0 ≤ Operational ≤ 9.7
Conductivity (mS/m) (at 25 °C)	28.0	Aesthetic ≤170
Total Dissolved Solids (mg/L)	189.84	Aesthetic ≤1200
Turbidity (NTU)	27.30	Operational ≤1 Aesthetic ≤5
Colour (mg/L as Pt)	<15	Aesthetic ≤15
Sodium (mg/L as Na)	37	Aesthetic ≤200
Potassium (mg/L as K)	4	N/A
Magnesium (mg/L as Mg)	4	N/A
Calcium (mg/L as Ca)	7	N/A
Chloride (mg/L as Cl)	64.43	Aesthetic ≤300
Sulphate (mg/L as SO ₄)	6.86	Aesthetic ≤250 Acute ≤500
Nitrate & Nitrite Nitrogen (mg/L as N)	0.068	≤1 Acute Health
Nitrate Nitrogen (mg/L as N)	<1.00	Acute Health ≤11
Nitrite Nitrogen (mg/L as N)	<0.05	Acute Health ≤0.9
Ammonia Nitrogen (mg/L as N)	<0.15	Aesthetic ≤1.5
Total Alkalinity (mg/L as CaCO ₃)	25.1	N/A
Total Hardness (mg/L as CaCO ₃)	33.9	N/A
Fluoride (mg/L as F)	0.16	Chronic Health ≤1.5
Aluminium (mg/L as Al)	0.217	Operational ≤0.3
Total Chromium (mg/L as Cr)	<0.004	Chronic Health ≤0.05
Manganese (mg/L as Mn)	0.045	Aesthetic ≤0.1 Chronic ≤0.4
Iron (mg/L as Fe)	0.549	Aesthetic ≤0.3 Chronic ≤2
Nickel (mg/L as Ni)	<0.008	Chronic Health ≤0.07
Copper (mg/L as Cu)	0.005	Chronic Health ≤2
Zinc (mg/L as Zn)	0.716	Aesthetic ≤5
Arsenic (mg/L as As)	<0.010	Chronic Health ≤0.01
Selenium (mg/L as Se)	<0.008	Chronic Health ≤0.04
Cadmium (mg/L as Cd)	<0.001	Chronic Health ≤0.003
Antimony (mg/L as Sb)	<0.013	Chronic Health ≤0.02
Mercury (mg/L as Hg)	0.002	Chronic Health ≤0.006
Lead (mg/L as Pb)	<0.008	Chronic Health ≤0.01
Uranium (mg/L as U)	<0.028	Chronic Health ≤0.03
Cyanide (mg/L as CN ⁻)	<0.01	Acute Health ≤0.2
Total Organic Carbon (mg/L as C)	1.74	N/A
Charge Balance Error %	0.5	≥-5 - ≤5 Acceptable

Table 6: Classified production borehole results according to DWAF 1998.

Sample Marked:	ECA_BH1	DWAF (1998) Drinking Water Assessment Guide				
		Class 0	Class I	Class II	Class III	Class IV
		Ideal	Good	Marginal	Poor	Dangerous
Date and Time Sampled	03/09/2024 15:00					
pH	6.0	5-9.5	4.5-5 & 9.5-10	4-4.5 & 10-10.5	3-4 & 10.5-11	< 3 & >11
Conductivity (mS/m)	28.0	<70	70-150	150-370	370-520	>520
Turbidity (NTU)	27.30	<0.1	0.1-1	1.0-20	20-50	>50
		mg/L				
Total Dissolved Solids	189.84	<450	450-1000	1000-2400	2400-3400	>3400
Sodium (as Na)	37	<100	100-200	200-400	400-1000	>1000
Potassium (as K)	4	<25	25-50	50-100	100-500	>500
Magnesium (as Mg)	4	<70	70-100	100-200	200-400	>400
Calcium (as Ca)	7	<80	80-150	150-300	>300	
Chloride (as Cl)	64.43	<100	100-200	200-600	600-1200	>1200
Sulphate (as SO ₄)	6.86	<200	200-400	400-600	600-1000	>1000
Nitrate & Nitrite (as N)	0.068	<6	6.0-10	10.0-20	20-40	>40
Fluoride (as F)	0.16	<0.7	0.7-1.0	1.0-1.5	1.5-3.5	>3.5
Manganese (as Mn)	0.045	<0.1	0.1-0.4	0.4-4	4.0-10.0	>10
Iron (as Fe)	0.549	<0.5	0.5-1.0	1.0-5.0	5.0-10.0	>10
Copper (as Cu)	0.005	<1	1-1.3	1.3-2	2.0-15	>15
Zinc (as Zn)	0.716	<20	>20			
Arsenic (as As)	<0.010	<0.010	0.01-0.05	0.05-0.2	0.2-2.0	>2.0
Cadmium (as Cd)	<0.001	<0.003	0.003-0.005	0.005-0.020	0.020-0.050	>0.050
Hardness (as CaCO ₃)	33.900	<200	200-300	300-600	>600	
Charge Balance Error %	0.5	≥-5 - ≤5 Acceptable				

A number of chemical diagrams have been plotted for the groundwater sample and these are useful for chemical characterisation of the water and illustrate the similarities and differences in the water types. The Stiff Diagram is a graphical representation of the equivalent concentrations of the cations (positive ions) and anions (negative ions). This diagram shows concentrations of cations and anions relative to each other and direct reference can be made to specific salts in the water. From **Figure 6**, ECA_BH1 is classified as a Sodium & Potassium/Chloride hydrofacies. This is expected of groundwater hosted in the sandstone of the Rietvlei formation.




Figure 6: Stiff diagram of the groundwater sample (ECA_BH1).

The Sodium Adsorption Ratio (SAR) of the groundwater is plotted in **Figure 7**. ECA_BH1 plots as S1/C2, thus classified as low risk in terms of sodium adsorption and medium risk in terms of salinity hazard. This graph is typically applicable to irrigation, however, is dependent on soil texture and crop type.




Figure 7: SAR diagram of the groundwater sample (ECA_BH1).

4 Recommendations

Based on the information obtained from the yield test, the abstraction recommendation for the borehole is presented in **Table 7**. The yield testing was conducted with a Step Test, Constant Discharge Test and Recovery Test and while this data can be analysed to estimate sustainable yields, additional drilling in the area may result in long term cumulative impacts. Optimisation of the resource is also likely through making small changes to the abstraction rate, should the dynamic water level's drawdown be less or more than expected as per **Table 7**. Both of these points are best managed through long term monitoring data.

Table 7: Borehole Abstraction Recommendations.

Borehole Details				
Borehole Name	Latitude (DD, WGS84)	Longitude (DD, WGS84)	Borehole Depth (m)	Inner Diameter (mm)
ECA_BH1	-34.30790°	19.47264°	138.6	177
Abstraction Recommendations				
Borehole Name	Abstraction rate (L/s)	Abstraction Duration (hrs)	Recovery Duration (hrs)	Possible Volume Abstracted (L/d)
ECA_BH1	1.5	24	0	129 600
Pump Installation Details				
Borehole Name	Pump Installation Depth (mbgl)	Critical Water Level (mbgl)	Dynamic Water Level (mbgl)*	Rest Water Level (mbgl)
ECA_BH1	66	63	29	8.23

* Typical water level expected during long-term production

For borehole ECA_BH1 it is recommended that abstraction can occur at a rate of up to 1.5 L/s for 24 hours per day. A pump suitable to deliver the recommended rate should be installed at a depth of 66 mbgl. It is anticipated that abstraction at the recommended rate will cause the water level to drop to a depth of approximately 29 mbgl – this is referred to as the dynamic water level. During abstraction, a maximum level cut off switch should be installed to 63 mbgl to ensure the groundwater level does not drop to the pump inlet.

From the laboratory results, groundwater from ECA_BH1 is of poor quality for potable use. The primary issue is elevated turbidity, measured at 27.3 NTU, which exceeds the SANS 241-1:2015 aesthetic standard. This level of turbidity is likely due to fine sediments entering the borehole, and it causes aesthetic issues such as cloudiness in the water. Although some of the turbidity may clear up during borehole development, the presence of elevated iron (0.549 mg/L) poses additional concerns. High iron levels can lead to aesthetic problems like red staining on walls and infrastructure, and they increase the risk of iron biofouling. If not managed properly, biofouling could clog the borehole and associated abstraction infrastructure.

To address the potential for iron to clog the borehole and abstraction infrastructure, it is recommended to maintain a constant and continuous pumping schedule as much as possible. Thus, should a daily volume of less than 129 600 L/d be required, it is recommended to decrease the pumping rate and not the pumping duration. By pumping continuously instead of on a stop-start schedule, iron oxidation in the borehole is minimized, decreasing the amount of iron precipitation inside the boreholes and pumps.

Through long term water level monitoring data, the abstraction volumes can be optimised by adjusting

the abstraction rate if required. It is recommended that the borehole is equipped with a variable frequency drive. This enables adjustments to the flow rate to be made if required, as determined by the hydrogeological analysis of water level and flow rate monitoring data.

As of January 2018 the Department of Water and Sanitation released a Government Gazette stating that: "All water use sector groups and individuals taking water from any water resource (surface or groundwater) regardless of the authorization type, in the Berg, Olifants and Breede Gouritz Water Management Area, shall install electronic water recording, monitoring or measuring devices to enable monitoring of abstractions, storage and use of water by existing lawful users and establish links with any monitoring or management system as well as keep records of the water used."

Therefore, to facilitate monitoring and informed management of the borehole, it is highly recommended that the borehole be equipped with the following monitoring infrastructure and equipment (diagram included in **Appendix D**):

- Installation of a 32 mm (inner diameter, class 10) observation pipe from the pump depth to the surface, closed at the bottom and slotted for the bottom 5 – 10 m.
- Installation of an electronic water level logger (for automated water level monitoring).
- Installation of a sampling tap (to monitor water quality).
- Installation of a flow volume meter (to monitor abstraction rates and volumes).

This monitoring data should be analysed by a qualified Hydrogeologist to ensure long-term sustainable use from the borehole. The legal compliance with regard to the use of the groundwater also needs to be addressed with the Department of Water and Sanitation.

5 References

- Barker, J.A., (1988). A Generalised Radial Flow Model for Hydraulic Tests in Fractured Rock. *Water Resources Research*, Vol. 24, No. 10 Pages 1796 – 1804.
- Council for Geoscience (1997). The 1: 250 000 geological map series Map number: 3319 Worcester.
- DWAF (1998). Quality of domestic water supplies, Volume 1: Assessment guide. Department of Water Affairs and Forestry, Department of Health, Water Research Commission, 1998.
- Todd, D.K. (1980). *Groundwater Hydrology*, 2nd ed., John Wiley & Sons, New York, 535p.
- Kruseman, G.P. & de Ridder, N.A. (1990). *Analysis and Evaluation of pumping test data*. 2nd edition, International Institute for Land Reclamation and Improvement (ILRI).
- Meier, P.M., Carrera, J. & Sanchez-Vila, X. (1998). An evaluation of Jacob's method for the interpretation of pumping tests in heterogeneous formations. *Water Resources Research*, Vol. 34, No. 5. 1011 – 1025.
- National Water Act (1998). The National Water Act, No 36. Department of Water Affairs and Forestry. Pretoria.
- SANS (10299-4:2003). South African National Standard. Development, maintenance and management of groundwater resources. Part 4: Test-pumping of water boreholes. ISBN 0-626-14912-6.
- SANS (241-1:2015). Drinking water – Part 1: Microbiological, physical, aesthetic and chemical determinants.

6 Appendix A: Borehole Log

Log of Borehole No.: ECA_BH1			
Location:	EFRC Agri Caledon	Latitude:	-34.3079
Date:	15-Aug-24	Longitude:	19.47264
Client:	EFRC Agri	Ground Elevation:	237 mamsl
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Overburden	0		
Weathered sandstone	20		
	40		
	60		
	80		
Sandstone	100		
	120		
	140		
Drilled By:	RPM Drilling	Remarks:	Blow yield: 60 000 L/h
Drill Method:	Air percussion		
Logged By:	RPM Drilling		

7 Appendix B: Yield Test Data

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPM	Revolutions per minute
SWL	Static water level
µS/cm	Microsiemens per centimeter

BOREHOLE TEST RECORD

ATS

CONSULTANT: GEOSS
 DISTRICT: OVERBERG
 PROVINCE: WESTERN CAEP
 FARM / VILLAGE NAME : ELGIN CHICKEN FARM
 DATE TESTED: 31/07/2024

PROJECT #	P2987
TEAM MEMBERS	MZIMKHULU
	ISAAC
	LUKHANYO

BOREHOLE LOCATION & ACCESS INFORMATION:	
BOREHOLE COORDINATES	COMMENTS ON ACCESS IF ANY:
LATITUDE (SOUTH):	34.3079
LONGITUDE (EAST):	19.47264
BOREHOLE NO:	ECA-BH1
TRANSMISSIVITY VALUE:	
TYPE INSTALLATION:	NEW BOREHOLE
BOREHOLE DEPTH: (mbg)	138.6

MAINTENANCE RECORD:	REHABILITATION RECORD:	DIGITAL CAMERA LOGGING:	EQUIPMENT FISHING RECORD
Labour hours:	Jetting hours:	Camera logged once:	Hours spent:
Cost of material:	Brushing hours:	Camera logged twice:	
Travelling (km):	Airlifting hours:	Camera logged three times:	OTHER COSTS ON PROJECT:
	Sulphamic Acid KG's	Camera work sent to client:	Courier of samples:
	Boresaver KG's		Km's for delivery:
	Soda Ash KG's		Cost of packaging:
COMMENTS:		RECOMMENDATIONS / CORRECTIVE ACTIONS:	

SAMPLE INSTRUCTIONS :					
Water sample taken	Yes	No	If consultant took sample, give name:		DATA CAPTURED BY: EC
Date sample taken	03/08/2024		If sample courier, to where:		DATA CHECKED BY: AVN
Time sample taken	15H00				

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	138.60
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	12.7
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ SIGNATURE: _____
 DESIGNATION: _____ DATE: _____

FORM 5 E

STEPPED DISCHARGE TEST & RECOVERY

BOREHOLE TEST RECORD SHEET

PROJ NO : P2987

BOREHOLE NO: ECA-BH1

ALT BH NO: 0

ALT BH NO: 0

Coordinates: SOUTH: 34.3079

EAST: 19.47264

PROVINCE: WESTERN CAEP

DISTRICT: OVERBERG

SITE NAME: ELGIN CHICKEN FARM

BOREHOLE DEPTH (m) 138.60

DATUM LEVEL ABOVE CASING (m): 0.32

EXISTING PUMP: 0

WATER LEVEL (m bdl): 8.94

CASING HEIGHT: (magl): 0.39

CONTRACTOR: ATS

DEPTH OF PUMP (m): 118.50

DIAMPUMP INLET (mm): 170.00

PUMP TYPE: WA 110-2

STEPPED DISCHARGE TEST & RECOVERY

DISCHARGE RATE 1

276

DISCHARGE RATE 2

RPM 434

DISCHARGE RATE 3

RPM 618

DATE: 31/07/2022

TIME: 12H40

DATE: 31/07/2022

TIME: 13H40

DATE: 31/07/2022

TIME: 14H40

TIME

DRAW

YIELD

TIME

RECOVERY

TIME

DRAW

YIELD

TIME

RECOVERY

TIME

DRAW

YIELD

TIME

RECOVERY

(MIN)

DOWN (M)

(L/S)

(MIN)

(M)

(MIN)

DOWN (M)

(L/S)

(MIN)

(M)

(MIN)

DOWN (M)

(L/S)

(MIN)

(M)

1

1.08

1

1

13.96

1

1

30.22

1

2

2.13

2

2

14.24

10.96

2

2

31.84

2

3

2.83

3

3

14.37

3

3

33.08

3

5

3.50

5

5

15.12

12.52

5

5

35.17

17.45

5

7

4.28

6.25

7

7

16.04

7

7

37.43

7

10

5.50

10

10

18.43

13.00

10

10

39.27

18.09

10

15

8.25

8.02

15

15

19.90

15

15

43.63

15

20

9.20

8.09

20

20

21.62

13.04

20

20

47.17

18.14

20

30

10.85

30

30

23.13

13.10

30

30

53.07

18.11

30

40

11.98

8.12

40

40

25.63

40

40

56.03

40

50

12.77

50

50

27.30

13.12

50

50

58.02

18.06

50

60

13.49

8.04

60

60

29.57

60

60

61.28

60

70

70

70

70

70

70

80

80

80

80

80

80

90

90

90

90

90

90

100

100

100

100

100

100

110

110

110

110

110

110

120

120

120

120

120

120

pH

150

pH

150

pH

150

TEMP

22.10

°C

180

TEMP

17.80

°C

180

TEMP

16.20

°C

180

EC

288

µS/cm

210

EC

274

µS/cm

210

EC

256

µS/cm

210

DISCHARGE RATE 4

RPM

DISCHARGE RATE 5

RPM

DISCHARGE RATE 6

RPM

DATE: 31/07/2024

TIME: 15H40

DATE:

TIME:

DATE:

TIME:

TIME

DRAW

YIELD

TIME

RECOVERY

TIME

DRAW

YIELD

TIME

RECOVERY

TIME

DRAW

YIELD

TIME

RECOVERY

(MIN)

DOWN (M)

(L/S)

(MIN)

(M)

(MIN)

DOWN (M)

(L/S)

(MIN)

(M)

(MIN)

DOWN (M)

(L/S)

(MIN)

(M)

1

62.30

1

38.96

1

1

1

1

2

63.43

2

28.91

2

2

2

2

3

65.62

3

25.89

3

3

3

3

5

71.61

21.24

5

25.00

5

5

5

5

7

77.02

7

21.24

7

7

7

7

10

83.86

22.28

10

19.17

10

10

10

10

15

15

17.67

15

15

15

15

20

20

16.56

20

20

20

20

30

30

14.49

30

30

30

30

40

40

12.95

40

40

40

40

50

50

11.57

50

50

50

50

60

60

10.76

60

60

60

60

70

70

10.03

70

70

70

70

80

80

9.66

80

80

80

80

90

90

9.28

90

90

90

90

100

100

8.68

100

100

100

100

110

110

8.16

110

110

110

110

120

120

7.67

120

120

120

120

pH

150

6.99

pH

150

pH

150

TEMP

°C

180

6.27

TEMP

°C

180

TEMP

°C

180

EC

µS/cm

210

EC

µS/cm

210

EC

µS/cm

210

240

240

240

300

300

300

360

360

360

SW/L:(mbch)

8.97

Report No: 2024/08-19

20

GEOSS

FORM 5 F													
CONSTANT DISCHARGE TEST & RECOVERY													
BOREHOLE TEST RECORD SHEET													
PROJ NO: P2987				Coordinates: SOUTH: 34.3079				PROVINCE: WESTERN CAEP					
BOREHOLE NO: ECA-BH1				EAST: 19.47264				DISTRICT: OVERBERG					
ALT BH NO: 0								SITE NAME: ELGIN CHICKEN FARM					
BOREHOLE DEPTH: 138.60				DATUM LEVEL ABOVE CASING (m): 0.32				EXISTING PUMP: 0					
WATER LEVEL (mbdl): 9.28				CASING HEIGHT: (magl): 0.39				CONTRACTOR: ATS					
DEPTH OF PUMP (m): 118.50				DIAM PUMP INLET(mm): 170				PUMP TYPE: WA 110-2					
CONSTANT DISCHARGE TEST & RECOVERY													
TEST STARTED						TEST COMPLETED							
DATE: 01/08/2024		TIME: 13H00				DATE:		TIME:				TYPE OF PUMP: WA 110-2	
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3			
						NR:		NR:		NR:			
DISCHARGE BOREHOLE						Distance(m):		Distance(m):		Distance(m):			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)		TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	2.64		1	56.57		1			1			1	
2	3.00		2	51.91		2			2			2	
3	3.92		3	50.74		3			3			3	
5	5.26		5	48.76		5			5			5	
7	8.02	11.68	7	47.02		7			7			7	
10	10.63		10	44.98		10			10			10	
15	14.41	13.46	15	42.96		15			15			15	
20	16.09		20	41.90		20			20			20	
30	19.56	15.06	30	39.60		30			30			30	
40	21.20		40	37.02		40			40			40	
60	28.96	15.10	60	34.23		60			60			60	
90	34.71	15.08	90	30.70		90			90			90	
120	39.76		120	27.57		120			120			120	
150	43.21	15.02	150	25.08		150			150			150	
180	46.02		180	23.52		180			180			180	
210	49.00	15.11	210	22.06		210			210			210	
240	51.26		240	21.09		240			240			240	
300	54.08	15.03	300	18.95		300			300			300	
360	58.10	15.07	360	17.00		360			360			360	
420	61.24		420	15.40		420			420			420	
480	64.82	15.12	480	14.02		480			480			480	
540	68.00		540	12.88		540			540			540	
600	71.09	15.07	600	11.87		600			600			600	
720	77.20		720	10.31		720			720			720	
840	83.45	15.10	840	9.01		840			840			840	
960	94.98		960	7.87		960			960			960	
		12.35	1080	6.97		1080			1080			1080	
		12.19	1200	6.13		1200			1200			1200	
		11.98	1320	5.39		1320			1320			1320	
			1440	4.63		1440			1440			1440	
			1560			1560			1560			1560	
			1680			1680			1680			1680	
			1800			1800			1800			1800	
			1920			1920			1920			1920	
			2040			2040			2040			2040	
			2160			2160			2160			2160	
			2280			2280			2280			2280	
			2400			2400			2400			2400	
			2520			2520			2520			2520	
			2640			2640			2640			2640	
			2760			2760			2760			2760	
			2880			2880			2880			2880	
			3000			3000			3000			3000	
			3120			3120			3120			3120	
			3240			3240			3240			3240	
			3360			3360			3360			3360	
			3480			3480			3480			3480	
			3600			3600			3600			3600	
			3720			3720			3720			3720	
			3840			3840			3840			3840	
			3960			3960			3960			3960	
			4080			4080			4080			4080	
			4200			4200			4200			4200	
			4320			4320			4320			4320	
Total time pumped(min):						W/L			W/L			W/L	
Average yield (l/s):													

FORM 5 F															
CONSTANT DISCHARGE TEST & RECOVERY															
BOREHOLE TEST RECORD SHEET															
PROJ NO:		P2987		Coordinates: SOUTH: 34.3079				PROVINCE:		WESTERN CAEP					
BOREHOLE NO:		ECA-BH1		EAST: 19.47264				DISTRICT:		OVERBERG					
ALT BH NO:		0						SITE NAME:		ELGIN CHICKEN FARM					
ALT BH NO:		0													
BOREHOLE DEPTH: 138.60				DATUM LEVEL ABOVE CASING (m): 0.32				EXISTING PUMP: 0							
WATER LEVEL (mbdl): 13.69				CASING HEIGHT: (magl): 0.39				CONTRACTOR: ATS							
DEPTH OF PUMP (m): 118.50				DIAM PUMP INLET(mm): 170				PUMP TYPE: WA 110-2							
CONSTANT DISCHARGE TEST & RECOVERY															
TEST STARTED						TEST COMPLETED									
DATE:		03/08/2024		TIME:		08H20		DATE:				TIME:			
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3					
						NR:		NR:		NR:					
DISCHARGE BOREHOLE						Distance(m):		Distance(m):		Distance(m):					
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME MIN	RECOVERY (M)	TIME: (min)	Drawdown (m)	Recovery (m)	TIME: (min)	Drawdown (m)	Recovery (m)	TIME: (min)	Drawdown (m)			
1	5.74		1	35.02	1			1			1				
2	6.90		2	31.16	2			2			2				
3	8.19		3	28.68	3			3			3				
5	10.04	10.62	5	26.02	5			5			5				
7	11.63		7	24.74	7			7			7				
10	15.74	12.54	10	23.54	10			10			10				
15	17.00	12.52	15	21.51	15			15			15				
20	19.33		20	20.47	20			20			20				
30	21.03	12.50	30	18.73	30			30			30				
40	24.16		40	17.62	40			40			40				
60	27.95	12.54	60	16.35	60			60			60				
90	30.49	12.56	90	14.51	90			90			90				
120	32.98		120	13.00	120			120			120				
150	35.84	12.52	150	11.68	150			150			150				
180	38.06		180	10.59	180			180			180				
210	40.50	12.57	210	9.36	210			210			210				
240	43.12	12.56	240	8.61	240			240			240				
300	49.91	12.58	300		300			300			300				
360	49.91	12.58	360		360			360			360				
420	52.70		420		420			420			420				
			480		480			480			480				
			540		540			540			540				
			600		600			600			600				
			720		720			720			720				
			840		840			840			840				
			960		960			960			960				
			1080		1080			1080			1080				
			1200		1200			1200			1200				
			1320		1320			1320			1320				
			1440		1440			1440			1440				
			1560		1560			1560			1560				
			1680		1680			1680			1680				
			1800		1800			1800			1800				
			1920		1920			1920			1920				
			2040		2040			2040			2040				
			2160		2160			2160			2160				
			2280		2280			2280			2280				
			2400		2400			2400			2400				
			2520		2520			2520			2520				
			2640		2640			2640			2640				
			2760		2760			2760			2760				
			2880		2880			2880			2880				
			3000		3000			3000			3000				
			3120		3120			3120			3120				
			3240		3240			3240			3240				
			3360		3360			3360			3360				
			3480		3480			3480			3480				
			3600		3600			3600			3600				
			3720		3720			3720			3720				
			3840		3840			3840			3840				
			3960		3960			3960			3960				
			4080		4080			4080			4080				
			4200		4200			4200			4200				
			4320		4320			4320			4320				
Total time pumped(min):						W/L				W/L					
Average yield (l/s):															

8 Appendix C: Water Quality

TEST REPORT

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling

P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079

Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2024-08-08



@VinlabSA

Sample Details					
SampleID	W54284				
Water Type	Drinking Water				
Water Source	Borehole				
Sample Temperature					
Description	ECA_BH1				
Batch Number					
PO Number	3659_L				
Date Received	2024-08-06				
Condition	Good				

Water - Routine									
	Unit	Method	Uncertainty	Limit	Results	Results	Results	Results	Results
pH@25C (Water)		VIN-05-MW01	^^^	>= 5 to <= 9.7	6.01				
Conductivity@25C (Water)	mS/m	VIN-05-MW02	^	<= 170	28				
Turbidity (Water)*	ntu			<= 5	27.3				
Total dissolved solids (Water)*	mg/L			<= 1200	189.84				
Free Chlorine (Water)*	mg/L			<= 5	<0.02				
Ammonia (NH4) as N (Water)	mg/L	VIN-05-MW08	8.90%	<= 1.5	<0.15				
Nitrate as N (Water)	mg/L	VIN-05-MW08	11.00%	<= 11	<1.00				
Nitrite as N (Water)	mg/L	VIN-05-MW08	4.50%	<= 0.9	<0.05				
Chloride (Cl-) - Water	mg/L	VIN-05-MW08	10.12%	<= 300	64.43				
Sulphates (SO4) - Water	mg/L	VIN-05-MW08	7.56%	<= 500	6.86				
Fluoride (F) - Water	mg/L	VIN-05-MW08	12.30%	<= 1.5	0.16				
Alkalinity as CaCO3 (Water)*	mg/L				25.10				
Colour (Water)*	mg/L Pt-Co			<= 15	<15				
Total Organic Carbon (Water)*	mg/L			<= 10	1.74				
Date Tested					2024-08-06				

Water - Metals									
	Unit	Method	Uncertainty	Limit	Results	Results	Results	Results	Results
Calcium (Ca) - Water	mg/L	VIN-05-MW43	14.60%		7				
Magnesium (Mg) - Water	mg/L	VIN-05-MW43	8.49%		4				
Sodium (Na) - Water	mg/L	VIN-05-MW43	11.45%	<= 200	37				
Potassium (K) - Water	mg/L	VIN-05-MW43	9.42%		4				

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab.

Vinlab is not liable to any client for any loss or damages suffered which could, directly or remotely, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Py= pycnometer; W=winescan; AI=alcolyzer; W = Winescan. Micro results: Enumeration of yeast: WL nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO2 additions less than 10 days may depress the growth of microbes in culture although they are viable/active in the wine. Some microbes, especially lactobacilli, may not grow in culture even where viable/potentially active in the wine.

^ - Conductivity <1000µS/m = ±1mS/m, >1000µS/m = ±9mS/m
^^ - COD, LR = ±16mg/L, MR = ±48mg/L, HR = ±477mg/L
^^^ - pH ± 0.1

Doc No
V54919

VIN 09-01 07-05-2024

Page: 1 of 2

Visit Vinlab H2O



TEST REPORT

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling

P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079

Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2024-08-08



@VinlabSA

Zinc (Zn) - Water	mg/L	VIN-05-MW43	19.40%	<= 5	0.716				
Antimony (Sb) - Water*	µg/L			<-20	<13.0				
Arsenic (As) - Water*	µg/L			<= 10	<10.0				
Boron (B) - Water	µg/L	VIN-05-MW43	11.79%	<- 2400	13				
Cadmium (Cd) - Water	µg/L	VIN-05-MW43	12.26%	<- 3	<1				
Chromium (Cr) - Water	µg/L	VIN-05-MW43	13.03%	<- 50	<4				
Copper (Cu) - Water	µg/L	VIN-05-MW43	11.57%	<- 2000	5				
Iron (Fe) - Water	µg/L	VIN-05-MW43	12.49%	<- 2000	549				
Lead (Pb) - Water	µg/L	VIN-05-MW43	16.32%	<- 10	<8				
Manganese (Mn) - Water	µg/L	VIN-05-MW43	12.44%	<- 400	45				
Nickel (Ni) - Water	µg/L	VIN-05-MW43	17.38%	<- 70	<8				
Selenium (Se) - Water*	µg/L			<= 40	<10.0				
Aluminium (Al) - Water	µg/L	VIN-05-MW43	13.49%	<- 300	217				
Cyanide (CN) - Water*	µg/L			<= 200	<10.0				
Mercury (Hg) - Water*	µg/L			<- 6	2				
Barium (Ba) - Water	µg/L	VIN-05-MW43	14.09%	<- 700	29				
Uranium (U) - Water*	µg/L			<- 30	<28				
Date Tested					2024-08-06				

Comments

W54284
Ion balance = 0.5%

Adelize Fourie
Laboratory Manager (Waterlab)

VIN-05:
M01, M02, M03, M04, M05, M08, M10, M28,
M43, MW01, MW02, MW03, MW04,
MW05, MW06, MW07, MW08/9/10,
MW12, MW13, MW14

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab.

Vinlab is not liable to any client for any loss or damages suffered which could, directly or remotely, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Py= pycnometer; W=winescan; AI=alcoalyzer. W = Winescan. Micro results: Enumeration of yeast: WL nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO2 additions less than 10 days may depress the growth of microbes in culture although they are viable/active in the wine. Some microbes, especially lactobacilli, may not grow in culture even where viable/potentially active in the wine.

* - Conductivity <1000µS/m = ±1mS/m, >1000µS/m = ±9mS/m
** - COD, LR = ±16mg/L, MR = ±48mg/L, HR = ±477mg/L
*** - pH ± 0.1

Doc No
V54919


VIN 09-01 07-05-2024


Page: 2 of 2

Visit Vinlab H2O




9 Appendix D: Monitoring Infrastructure Diagram






10 Appendix E: Yield Test Data Analysis

ECA_BH1




FC - Non Linear Method to estimate Q_Sust					
Non-Darcian loss			Darcian loss		
A	C	p	B	n	e
1.00E-06	2.41E-06	2.16E+00	1.00E-03	5.00E-01	1.00E+00
Extrapolation					
Ext. pol time (min)					
1051200					
Q (L/s)			Drawdown (m)		
1			58.23		
Available drawdown (m) = 54					
No boundaries					
1 no-flow		2 no-flow		Closed	
1.0		0.5		0.3	
Q_Sust (L/s) = 0.71		std dev = 0.36		0.2	
Boundaries selected 0 - closed					

Blue Bar	Red Bar
58.23	54




Cooper-Jacob method


$T (m^2/d) =$	6.1	$r_w (m) =$	0.1	
$S =$	1.09E+01	$Q (l/s) =$	15.00	
	No boundaries	1 no-flow	2 no-flow	Closed
Q_sust	4.20	2.10	1.39	1.05
Avg. Q_sust =		2.19	std. dev =	1.41
Boundaries selected	0 - closed			




FC method			
Extrapolation time in years		Extrapolation time in minutes	
Effective borehole radius (r_w)	2	1051200	
43.1428199	43.1428199	Est. r_w	From (re) sheet
Q (l/s) from pumping test	15	0.000274289	S-rate
s_a (available drawdown), sigma s	54	0	Sigma s from risk
Annual effective recharge (mm)	0	54	s_a available working draw down (m)
t(end) and s(end) of pumping test	1060	109.12	End time and drawdown of test
Average maximum derivative	40.95	103.373784	Estimate of average of max deriv
Average second derivative	0.8	0.095270497	Estimate of average second deriv
Derivative at radial flow period	17.5525733	17.55257331	Read from derivative graph
T-early (m ² /d)	13.51186494		Aqu. thick (m)
T and S estimates			60
	T-late (m ² /d)	5.791648352	Est. S-rate
	S-rate	0.0033	0.0033
BASIC SOLUTION			
No boundaries			
1 no-flow		2 no-flow	
sWell (Extrapol time) =		480.82	
Q sust (l/s) =		1.68	
Average Q sust (l/s) =		0.95	
with standard deviation =		1.05	
Boundaries selected 0 - closed			



FC inflection point method			
extrapolation time in years =		2	1051200
t (min) and s(m) at inflection point =		380	58
enter derivative value at inflection point time =		46.49	46.48555
	No boundaries	1 no-flow	2 no-flow
sWell(Extrapol time)	218.01	378.03	538.04
Q sust	3.99	2.30	1.62
Average Q-sust (l/s)	1.89	std. dev =	0.85
Boundaries selected	0 - closed		



Barker method					
	K _i [m/d]	S _i [1/m]	b	n	N
Fit Parameters	150.00	2.00E-03	1.19	1.40	0.3000
			No boundaries		Closed
sWell(Extrapol time)			1 no-flow	2 no-flow	1255.86
			764.85	1010.25	1132.96
Q _{sust}			1.06	0.80	0.71
					0.65
Fractal n = 1.40	Average Q-sust (l/s)=		0.79		std. dev = 0.18
Boundaries selected			0 - closed		



Recovery	
T (m ² /d)	10.96
CDT Duration	1060
Recovery Duration	1440
Max % Recovery	95.8

(LAST PAGE)